

ICS 31.060.70
CCS K 42

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 740-2014

Replacing DL 740-2000

Capacitive type voltage detectors

电容型验电器

(English Translation)

Issued on: March 18, 2014

Implemented on: August 1, 2014

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard provides for the exchange of 10kV ~ 750kV power system capacitance type electroscopes definition, classification, technical requirements, test methods. This standard is applicable to the portable electroscopes used in the frequency AC power system of 10kV ~ 750kV in the area of 1000m and below. Applicable to the measured parts in contact with the capacitive electroscopes, not suitable for inductive non-contact electroscopes.

Document data

International classification (ICS): 31.060.70.

Chinese classification (CCS): K42.

Estimated length of the Chinese original: 36,344 words.

Adopted international standard: IEC 61243-1-2003, MOD.

Supersedes the earlier edition DL 740-2000.

Standards quoted by this document

GB/T 1800.1; GB/T 1800.2; GB/T 2421.1; GB/T 2423.8; GB/T 2423.10; GB/T 2423.22; GB/T 3241; GB/T 3767; GB/T 3785.1; GB/T 3979; GB/T 5465.2; GB 13398; GB/T 15173; GB/T 16927.1; DL/T 877; DL/T 972