

ICS 27.100
CCS F 21

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 860.92-2016

Replacing DL/T 860.92-2006

**Communication networks and systems for power utility
automation Part 9-2: Specific Communication Service
Mapping(SCSM)-Sampled values over ISO/IEC 8802-3**

电力自动化通信网络和系统 第9-2部分：特定通信服务映射(SCSM)-基于ISO/IEC 8802-3的采样值

(English Translation)

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This International Standard specifies the specific communication service mapping for transmission sample values ??defined in accordance with the abstract specification in part DL/T 860.72. It is an abstraction model based on a mixed protocol stack, which transfers sample values ??directly to the ISO/IEC 8802-3 link and also uses part of DL/T 860.81. Each specific service mapping (SCSM) consists of three parts: a detailed description of the protocol stack used; an abstract specification of the DL/T 860.7 part to the mapping method of the actual elements of the protocol stack; a specification of the functional implementation not included in the protocol stack.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F21.

Estimated length of the Chinese original: 30,327 words.

Adopted international standard: IEC 6180-9-2-2011, IDT.

Supersedes the earlier edition DL/T 860.92-2006.

Standards quoted by this document

IEC 61850-1-2013; IEC 61850-2-2003; IEC 61850-6-2009; IEC 61850-7-1-2011; IEC 61850-7-2-2010; IEC 61850-7-3-2010; IEC 61850-7-4-2010; IEC 61850-8-1-2011; IEC 62439-3-2010; ISO/IEC 7498-1-1994; ISO/IEC 8326-1996; ISO/IEC 8327-1-1996; ISO/IEC 8649-1996; ISO/IEC 8650-1-1