

ICS 77.040.01
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 999-2006

**The gradational standard of spheroidization for 2.25Cr-1Mo steel
used in power plant
(English Translation)**

Issued on: May 6, 2006

Implemented on: October 1, 2006

Issued by: National Development and Reform Commission

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the thermal power plant with a 2. 25Cr-1Mo steel ball of the rating methodology and rating criteria. This standard applies to 2. 25Cr-1Mo steel metal wall temperature less than 570°C superheated steam pipes, headers, steam conduit and other high temperature components used in high temperature conditions after long ball rating. Similar materials produced by the metal wall temperature below 580°C heating surface tubes ball grading may refer to.

Document data

International classification (ICS): 77.040.01.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 17,174 words.

Standards quoted by this document

GB 5310; GB/T 13298; DL/T 884; ASTM A213; ASTM A335; BS EN 10216-2; JIS G 3458; JIS G 3462