

ICS 13.220.20
CCS C 82

GA

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GA 587-2005

Maintenance for fire equipment in building

建筑消防设施的维护管理

(English Translation)

Issued on: December 26, 2005

Implemented on: May 1, 2006

Issued by: Ministry of Public Security of PRC

Table of Contents

- Foreword
- Introduction
- 1 Scope
- 2 Normative references
- 3 Terms and definitions
- 4 General

Foreword

4.1, 4.3, 4.4, 5, 6.1, 7.1, 8.1, 10, and 11 of this standard are mandatory provisions, and the rest are recommended.

Article.

Appendix A of this standard is a normative appendix.

This standard was proposed by the Fire Department of the Ministry of Public Security.

This standard is under the jurisdiction of the Ninth Technical Committee of the National Fire Protection Standardization Committee (SAC/TC113/SC9).

This standard was drafted. Fire Department of the Ministry of Public Security, Fire Department of the Jiangsu Provincial Public Security Department.

Introduction

Building fire protection facilities set up in accordance with relevant national laws and regulations and national engineering construction fire protection technical standards are fire prevention and timely rescue Effective measures to start a fire. Implement maintenance and management of building fire protection facilities to ensure their integrity and effectiveness, and is the property rights, management and use list of buildings.

Statutory duties. In order to guide and standardize the maintenance and management of building fire protection facilities, ensure that the building fire protection facilities are in good condition, according to the country.

This standard is formulated in accordance with the technical standards for fire protection.

Maintenance management of building fire protection facilities

1 Scope

This standard specifies the technical requirements for the maintenance and management of building fire protection facilities and provides methods.

This standard applies to the maintenance and management of building fire protection facilities.

2 Normative references

The terms in the following documents become the terms of this standard by reference to this standard. All dated references, followed by all Modifications (not including errata content) or revisions do not apply to this standard, however, parties to agreements based on this standard are encouraged to study if it is possible to use the latest version of these files? For undated references, the latest edition applies to this standard.

GB/T 14107 Basic Terms of Fire Fighting Part II GA 502 fire supervision technical equipment GA 503 Building Fire Protection Facilities Testing Technical Regulations

3 Terms and definitions

The following terms and definitions as defined in GB/T 14107 apply to this standard.

Inspection of the visual properties of building fire protection facilities.

Conduct technical testing of individual functions of various types of building fire protection facilities in accordance with relevant standards.

According to the relevant standards, the joint function test and comprehensive technical evaluation of all types of fire protection facilities in the whole building shall be carried out.

4 General

4.1

The management of building fire protection facilities should clarify the responsibilities of the competent departments and relevant personnel and establish a sound management system.

4.2

Building fire protection facilities inspection is divided into three methods. inspection, single inspection and linkage inspection.

4.3

The technical requirements and inspection methods for inspection, single inspection and linkage inspection of building fire protection facilities shall comply with the relevant

provisions of GA 503.

4.4

Management requirements.

a) The inspection of building fire protection facilities can be carried out by the department that manages the fire protection facilities, or according to the actual situation of work, production and operation.

In this case, the duties of the inspection will be carried out to relevant jobs.

b) Technical personnel engaged in single inspection and linkage inspection of construction fire protection facilities shall pass the fire safety examination and be certified to work.

The unit has professional technicians and testing equipment for single inspection and linkage inspection of building fire protection facilities, which can be in accordance with this standard.

It may be implemented on its own, or it may entrust a unit with the qualification of fire detection agency service or have the qualification for installation of the corresponding fire protection facilities.

The unit is implemented in accordance with this standard.

c) The joint inspection record of the building fire protection facilities and the linkage inspection record of the building fire protection facilities shall be signed by the inspection personnel and the inspection unit.

chapter. The inspection and inspection records of the building fire protection facilities and the linkage inspection of the building fire protection facilities issued by the testing personnel and the testing unit Record (see Appendix A) is responsible.