

ICS 29.060.20

CCS K13



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 12972.2-2008

Replacing GB 12972.2-1991

**Flexible rubber-sheathed cables for mining purposes - Part 2:
Flexible coalcutter cables for rated voltages up to 1.9/3.3kV**

矿用橡套软电缆 第2部分：额定电压1.9/3.3kV及以下采煤机软电缆

Issued on: June 30, 2008

Implemented on: April 1, 2009

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China;
Standardization Administration of China**

Table of Contents

- 1 Scope
- 2 Normative references
- 3 Use Characteristics

Foreword

GB/T 12972 "mining rubber flexible cable" is divided into 10 parts.

- Part 1. General requirements;
- Part 2. Rated voltage 1.9/3.3kV and below Shearer flexible cables;
- Part 3. rated voltage of 0.66/1.14kV Shearer shielded monitor enhanced flexible cables;
- Part 4. Rated voltage 1.9/3.3kV and below Shearer metal shield soft cable;
- Part 5. rated voltage of 0.66/1.14kV and following mobile rubber soft cable;
- Part 6. Rated voltage 6/10kV and below the metal shield Flexible cables with monitoring;
- Part 7. rated voltage 6/10kV and below shielded rubber-sheathed cables;
- Part 8. Rated voltage 0.3/0.5kV drill cables;
- Part 9. Rated voltage 0.3/0.5kV light mine mobile rubber soft cable;
- Part 10. Miner 's cap lamp cords. This section GB/T 12972 Part 2. This Part replaces GB 12972.2-1991 "mining rubber-sheathed cables - Part 2. Rated voltage 0.66/1.14kV Mining and below Coal cutter flexible cable. " This section compared with GB 12972.2-1991 main changes are as follows:
 - Name changed to "rated voltage 1.9/3.3kV and below Shearer flexible cables";
 - Increasing the rated voltage UCP-1.9/3.3kV Shearer flexible cable (Excerpts of Table 1);
 - Rated voltage U_0/U of 0.66/1.14kV cable specifications by the conductor cross-section 35mm² ~ 95mm² to 35mm² ~ 120mm² (1991 edition Table 2b; Excerpts of Table 3);

1 Scope

GB/T 12972.2-2008 is the Chinese national standard on flexible rubber-sheathed cables for mining purposes - part 2: flexible coalcutter cables for rated voltages up to 1.9/3.3kv, in the field of electrical engineering. The /T suffix marks it as a recommended standard: it is not compulsory by itself, but it becomes binding as soon as a contract, a tender or a customer

specification calls it up - which in practice is how most foreign buyers meet it. It was issued on 30 June 2008 by the General Administration of Quality Supervision, Inspection and Quarantine of the People's Republic of China; Standardization Administration of China, and has been in force since 1 April 2009. Classification: ICS 29.060.20, CCS K13. This page is published from the official record of the standard held by the Chinese standards administration: the identification, the dates, the classification and the issuing body are taken from there. The clause text, the tables and the numeric limits are in the document itself, which is delivered complete in English translation.

This section GB/T 12972 specifies the rated voltage 1.9/3.3kV and below Shearer cable product variety, technical requirements, test Methods and inspection rules. This section applies to the rated voltage U₀/U is 1.9/3.3kV and below Shearer and similar equipment copper core rubber insulated rubber protection Sheathed cables. This section should be GB/T 12972.1-2008 common use.

2 Normative references

The following documents contain provisions which, through reference

GB/T 12972 in this section constitute provisions of this section. For dated reference documents Member, all subsequent amendments (not including errata content) or revisions do not apply to this section, however, encouraged to reach under this section Parties to research agreement to use the latest versions of these documents. For undated reference documents, the latest versions apply to this section.

GB/T 2951.11-2008 cable and the cable Common test methods for insulating and sheathing materials - Part 11. General test side Law

--- Measurement of thickness and overall dimensions of mechanical tests (IEC 60811-1-1.1993, IDT)

GB/T 2951.12-2008 cable and the cable Common test methods for insulating and sheathing materials - Part 12. General test side Law

--- Thermal aging methods (

IEC 60811-1-2. 1985, IDT)

GB/T 2951.21-2008 cable and the cable Common test methods for insulating and sheathing materials - Part 21. elastomeric compounds designed Test method for ozone resistance test

--- Hot set test - Mineral oil immersion tests (

IEC 60811-2-1. 1986, IDT)

GB/T 3048.4-2007 electrical wire and cable performance test methods - Part 4. Conductor

DC resistance test

GB/T 3048.5-2007 electrical wire and cable performance test methods - Part 5. Insulation resistance test

GB/T 3048.8-2007 electrical wire and cable performance test methods - Part 8. AC voltage test (IEC 60060-1. 1989, NEQ)

GB/T 4909.2-1985 Test methods for bare wires sizing (neq IEC 60251. 1978)

3 Use Characteristics

3.1 Rated voltage U_0/U of 0.38/0.66kV, 0.66/1.14kV and 1.9/3.3kV.

3.2 cable conductor long-term allowable working temperature of 65 °C.

3.3 cable minimum bend radius of 6 times the cable diameter.