

ICS 29.060.20

CCS K 13



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 13033.1-2007

Replacing GB/T 13033.1-1991; GB/T 13033.3-1991

**Mineral insulated cables and their terminations with a rated
voltage not exceeding 750V -- Part 1: Cables**

额定电压750V及以下矿物绝缘电缆及终端 第1部分：电缆

(English Translation)

Issued on: January 16, 2007

Implemented on: August 1, 2007

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China, Standardization
Administration of the People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard applies to the rated voltage 500V and 750V copper or copper alloy copper mineral insulated sheathed general wiring cables, if needed, could be extruded copper sheath outer layer anticorrosion coat. Jacket is not a metal sheath electrical insulation. Cable terminal requirements, see GB/T 13033. 2. This section specifies the requirements and characteristics in order to make the manufacture of mineral insulated cables when used properly are safe and reliable, and provides detection test methods that meet these requirements.

Document data

International classification (ICS): 29.060.20.

Chinese classification (CCS): K13.

Estimated length of the Chinese original: 18,136 words.

Adopted international standard: IEC 60702-1-2002, IDT.

Supersedes the earlier edition GB/T 13033.1-1991; GB/T 13033.3-1991.

Standards quoted by this document

GB/T 2951.1