

ICS 31.2
CCS K 52



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 14024-1992

**Limits and methods of measurement of radio interference
characteristics of electric power plant with internal combustion
engines. Conducted interference**
(English Translation)

Issued on: December 28, 1992

Implemented on: August 1, 1993

Issued by: State Bureau of Technical Supervision

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This Standard specifies 0.75 ~ 3200kW internal combustion power plants conducted interference voltage measurement method and the allowable value. This Standard is applicable to an internal combustion engine as the prime mover driving frequency, IF, dual-engine DC generator and power plant (hereinafter referred to as power stations, including auto power station, trailer power plant, portable generators, stationary generators).

Document data

International classification (ICS): 31.2.

Chinese classification (CCS): K52.

Estimated length of the Chinese original: 6,636 words.

Adopted international standard: IEC 60533, NEQ.

Standards quoted by this document

GB 3907; GB 4365; GB 5320; GB 6113