

ICS 91.140.50
CCS Q 77



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 16895.9-2000

**Electrical installations of buildings. Part 7: Requirements for
special installations or locations. Section 707-Earthing
requirements for the installation of data processing equipment
(English Translation)**

Issued on: December 11, 2000

Implemented on: October 1, 2001

Issued by: State Quality and Technical Supervision

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard applies to: data processing device connected until that point is reached that part of the electrical device, Figure A1. This standard can also be used outside the data-processing equipment equipment, such as industrial control equipment and communications equipment electrical installations. Since the installation of those devices required for radio interference suppression filtering devices, while a large leakage current. Note: for data-processing equipment radio interference suppression Filters may have a great on the ground leakage current. Therefore, protective earth connection failure will form dangerous contact voltage, this standard the main purpose is to prevent such harm. This standard specific requirements applicable to data processing equipment in the following cases and building power devices Connection

Document data

International classification (ICS): 91.140.50.

Chinese classification (CCS): Q77.

Estimated length of the Chinese original: 9,912 words.

Adopted international standard: IEC 60364-7-707-1984; IDT.