

ICS 23.060.40; 25.040.40
CCS N 16



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 17213.17-2010

**Industrial-process control valves -- Part 2-5: Flow capacity --
Sizing equations for fluid flow through multistage control
valves with inter-stage recovery**

工业过程控制阀 第2-5部分：流通能力 流体流经级间恢复多级控制阀的计算公式
(English Translation)

Issued on: January 14, 2011

Implemented on: May 1, 2011

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China, Standardization
Administration of the People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the predicted flow through multistage control valves compressible and incompressible fluid flow calculation formula of. Incompressible fluid is calculated with the standard Newtonian incompressible fluid hydrodynamic equations is based. These formulas are not used for non-Newtonian fluids, liquid mixture, mixing the slurry or liquid-solid delivery systems. This standard applies only to multi-level multi-channel single-channel and multi-level control valve control valve.

Document data

International classification (ICS): 23.060.40; 25.040.40.

Chinese classification (CCS): N16.

Estimated length of the Chinese original: 26,238 words.

Adopted international standard: IEC 60534-2-5-2003, IDT.

Standards quoted by this document

GB/T 17213.1-1988; GB/T 17213.2-2005; GB/T 17213.9-2005