

ICS 33.100
CCS L 06



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 17626.13-2006

**Electromagnetic compatibility (EMC) - Testing and measurement
techniques - Harmonics and inter-harmonics including mains signalling
at a.c. power port low frequency immunity test**

电磁兼容 试验和测量技术 交流电源端口谐波、谐波间波及电网信号的低频抗扰度
试验

(English Translation)

Issued on: December 1, 2006

Implemented on: July 1, 2007

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China, Standardization
Administration of the People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the low-voltage grid with rated current up to 16A of electrical and electronic equipment on the harassment of the harmonic frequencies up to 2kHz, interharmonics immunity test methods, and puts forward the basic test level range. This part is not used to connect to 16Hz or 400Hz AC network electrical and electronic equipment, equipment for these networks test will be considered in other standards.

Document data

International classification (ICS): 33.100.

Chinese classification (CCS): L06.

Estimated length of the Chinese original: 22,258 words.

Adopted international standard: IEC 61000-4-13-2002, IDT.

Standards quoted by this document

GB/T 4365-2003; GB/T 17626.7-1998; GB/T 18039.3-2003; GB 17625.1-2003