



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 18216.2-2021

**Electrical safety in low voltage distribution systems up to 1 000 V a. c.
and 1 500 V d. c. - Equipment for testing, measuring or monitoring of
protective measures - Part 2: Insulation resistance**

Issued on: May 21, 2021

Implemented on: December 1, 2021

**Issued by: State Administration for Market Regulation, China National
Standardization Administration**

Table of Contents

1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Requirements	2
4.1 General requirements	2
4.2 Output voltage	2
4.3 Rated current	2
4.4 Measuring current	2
4.5 Influence of external capacitance	2
4.6 Overvoltage	2
5 Logo and instruction manual	3
5.1 Logo	3
5.2 Instruction Manual	3
6 Test.....	3
6.1 Overview	3
6.2 Work uncertainty	3
6.3 Open circuit voltage	4
6.4 Rated current	4
6.5 Measuring current	4
6.6 Overvoltage test	4
6.7 Battery life in battery-powered instruments	5
6.8 Stability test	5
Reference	6

Foreword

This document is in accordance with the provisions of GB/T 1.1-2020 "Guidelines for Standardization Work Part 1. Structure and Drafting Rules of Standardization Documents"

Drafting.

This document is GB/T 18216 "AC 1000V and DC 1500V and below low-voltage power distribution system electrical safety protection measures

Part 2 of "Testing, Measuring or Monitoring Equipment". GB/T 18216 has released the

following parts.

- Part 1.General requirements;
- Part 2.Insulation resistance;
- Part 3.Loop impedance;
- Part 4.Grounding resistance and equipotential grounding resistance;
- Part 5.Resistance to ground;
- Part 8.Insulation monitoring device in IT system;
- Part 9.Insulation fault location equipment in IT systems;
- Part 12.Performance Measurement and Monitoring Device (PMD).

This document replaces GB/T 18216.2-2012 "Electrical safety protection of low-voltage power distribution systems below 1000V AC and 1500V DC

Test, measurement or monitoring equipment for protective measures Part 2.Insulation resistance", compared with GB/T 18216.2-2012, except for structural adjustment and

In addition to editorial changes, the main technical changes are as follows.

- Added requirements for measurement categories (see 4.1);
- Added new requirements for the instruction manual (see 5.2).

The translation method used in this document is equivalent to the IEC 61557-2:2019 "AC 1000V and DC 1500V and below low-voltage power distribution system

Testing, measuring or monitoring equipment for integrated electrical safety protection measures. Part 2.Insulation resistance.

This document has made the following editorial changes.

- Added references.

Introduction

IEC 60364-6 specifies the first test, continuous monitoring and adjustment of these equipment in TN, TT or IT systems.

Standardized conditions for the post-adjustment test. In addition to the general standards that specify the implementation of these tests, IEC 60364-6 also includes

To verify the requirements. Only in a few cases, such as when measuring insulation resistance, does IEC 60364-6 include the measuring device used.

Details of the characteristics of the settings. Circuit diagrams given as examples in IEC

60364-6 and cited in the main text of the document are generally not applicable actual use.

When dangerous voltages appear in the electrical installation and the equipment is improperly used or defective, the implementation of the test in the electrical installation can easily cause concern.

outer. Therefore, in addition to simplifying the measurement, technicians also need to rely on measurement devices that ensure the safety of the measurement method.

The application of the general safety rules for electrical and electronic measuring devices (IEC 61010-1) for protective measures is in itself insufficient. in

Measurements in power installations are not only harmful to technicians, but also to third parties due to different measurement methods.

Similarly, in order to obtain an objective judgment about the equipment, such as periodic tests, continuous insulation monitoring, or

In the case of performance assurance, an important prerequisite is to use measurement devices from different manufacturers to obtain reliable and comparable measurement results.

The purpose of GB/T 18216 is to specify uniform principles that are consistent with the above characteristics. These principles are applicable to nominal voltage AC

Measuring and monitoring equipment for electrical safety test and performance test in 1000V and DC 1500V and below systems. GB/T 18216

It is proposed to consist of ten parts.

---Part 1.General requirements. The purpose is to establish a low-voltage power distribution system with nominal voltages of AC 1000V and DC 1500V and below

General requirements for test equipment used for electrical safety measurement and monitoring in the system.

---Part 2.Insulation resistance. The purpose is to establish that the measurement is suitable for the insulation of equipment and electrical installation equipment in a non-excited state

Relevant requirements for resistance equipment.

---Part 3.Loop impedance. The purpose is to establish between the measuring line conductor and the protective conductor, between the line conductor and the neutral conductor, or between the two conductors.

The relevant requirements of the loop impedance device between the line conductors.

---Part 4.Grounding resistance and equipotential grounding resistance. The purpose is to

establish the grounding conductor, protective grounding conductor and

And the relevant technical requirements for the resistance of the equipotential bonding conductor.

---Part 5. Resistance to ground. The purpose is to establish requirements for measuring equipment that uses AC voltage to measure resistance to earth.

---Part 6. Effectiveness of Residual Current Device (RCD) in TT, TN and IT systems. The purpose is to establish that the measurement is suitable for

Relevant requirements for test equipment for the effectiveness of protective measures for residual current devices in TT, TN and IT systems.

---Part 8. Insulation monitoring device in IT system. The purpose is to establish relevant requirements for insulation monitoring devices in IT systems.

---Part 9. Insulation fault location equipment in IT systems. The purpose is to establish the phase of insulation fault location equipment in the IT system.

Close requirements.

--- Part 10. Combination measuring equipment for testing, measuring or monitoring protective measures. The purpose is to establish test, measurement or monitoring

The related requirements of the equipment in which a variety of measurement functions or measurement methods are combined together.

---Part 12. Performance Measurement and Monitoring Device (PMD). The purpose is to establish a comprehensive measurement and monitoring of electrical parameters in the distribution system.

Meet the relevant requirements of performance measurement and monitoring devices.

AC 1000V and DC 1500V and below

Testing of electrical safety protection measures for low-voltage power distribution systems,

Measuring or monitoring equipment Part 2. Insulation resistance

1 Scope

This document specifies the requirements for measuring insulation resistance equipment, which are suitable for measuring equipment and electrical installations in a non-excited state

The insulation resistance of the equipment.

2 Normative references