

ICS 29.060.20

CCS K 13



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 19216.21-2003

Replacing GB/T 12666.6-1990

**Tests for electric cables under fire conditions -- Circuit integrity
-- Part 21: Procedures and requirements -- Cables of rated
voltage up to and including 0.6/1.0kV
(English Translation)**

Issued on: June 24, 2003

Implemented on: February 1, 2004

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the rated voltage 0.6/1.0kV and the following cables burning under fire conditions required to maintain circuit integrity test procedures and performance requirements, including the recommended time for the fire. This section provides a sample preparation method, continuity test unit, the electrical cables Test procedure and combustion method, and gives the results of the evaluation test requirements. This section applies to low-voltage power cables and control cables with a rated voltage.

Document data

International classification (ICS): 29.060.20.

Chinese classification (CCS): K13.

Estimated length of the Chinese original: 6,668 words.

Adopted international standard: IEC 60331-21-1999, IDT.

Supersedes the earlier edition GB/T 12666.6-1990.

Standards quoted by this document

GB/T 13539.5-1999; GB/T 19216.11-2003; IEC 104-1997