

ICS 29.130.10

CCS K 43



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 1984-2024

Replacing GB/T 1984-2014

High-voltage alternating-current circuit-breakers

高压交流断路器

(English Translation)

Issued on: September 29, 2024

Implemented on: April 1, 2025

**Issued by: State Administration for Market Regulation, China National
Standardization Administration**

Table of Contents

Preface
1 Scope
2 Normative references
3 Terms and Definitions
3.1 General Terms and Definitions
3.2 Final Assembly
3.3 Assembly components
3.4 Switchgear
3.5 Components of a circuit breaker
3.6 Operational characteristics
3.7 Characteristic parameters
3.8 Fault Type
4 Normal and special conditions of use
5 Rating
5.1 Overview
5.2 Rated voltage (U_r)
5.3 Rated insulation level (U_d , U_p and U_s)
5.4 Rated frequency (f_r)
5.5 Rated continuous current (I_r)
5.6 Rated short-time withstand current (I_k)
5.7 Rated peak withstand current (I_p)
5.8 Rated short circuit duration (t_k)
5.9 Rated supply voltage of auxiliary and control circuits (U_a)
5.10 Rated frequency of auxiliary and control circuit supply voltage
5.11 Rated pressure of compressed gas source for controlled pressure system
5.12 Rated filling pressure/level for insulation and/or switching
5.101 Rated short-circuit breaking current (I_{sc})
5.102 Rated first open pole coefficient (k_{pp})
5.103 Rated short-circuit making current
5.104 Rated operating sequence
5.105 Rated out-of-step closing and breaking current
5.106 Rated capacitive current

6 Design and structure

- 6.1 Requirements for liquid in circuit breakers
 - 6.2 Requirements for gas in circuit breakers
 - 6.3 Grounding of circuit breakers
 - 6.4 Auxiliary and control equipment and circuits
 - 6.5 Power Operation
 - 6.6 Energy storage operation
 - 6.7 Operation independent of non-locking (operation independent of manpower or power)
 - 6.8 Human-operated actuators
 - 6.9 Operation of the trip unit
 - 6.10 Pressure/Liquid Level Indicator
 - 6.11 Nameplate
 - 6.12 Interlocking device
 - 6.13 Position indication
 - 6.14 Degree of protection of enclosure
 - 6.15 Creepage distance of outdoor insulators
 - 6.16 Gas and vacuum sealing
 - 6.17 Liquid sealing
 - 6.18 Fire (flammability)
 - 6.19 Electromagnetic Compatibility (EMC)
 - 6.20 X-ray emission
 - 6.21 Corrosion
 - 6.22 Insulation and/or switching, operating filling pressure/level
 - 6.101 Requirements for inter-pole synchronization during single-close and single-break operations
 - 6.102 General requirements for operation
 - 6.103 Pressure limits of operating fluids
 - 6.104 Exhaust hole
 - 6.105 Time parameter
 - 6.106 Mechanical load
 - 6.107 Classification of circuit breakers
- ## 7 Type test
- 7.1 General Principles
 - 7.2 Insulation test
 - 7.3 Radio Interference Voltage Test (RIV)

- 7.4 Measurement of loop resistance
- 7.5 Continuous current test
- 7.6 Short-time withstand current and peak withstand current test
- 7.7 Protection level verification
- 7.8 Sealing test
- 7.9 Electromagnetic compatibility test (EMC)
- 7.10 Additional tests on auxiliary and control circuits
- 7.11 X-ray test of vacuum interrupter
- 7.101 Mechanical and environmental tests
- 7.102 Provisions for closing and opening tests
- 7.103 General principles for making and breaking tests
- 7.104 Explanation of arcing time
- 7.105 Short-circuit test parameters
- 7.106 Short circuit test procedure
- 7.107 Terminal fault test
- 7.108 Additional short-circuit test
- 7.109 Near-field fault test
- 7.110 Out-of-step closing and opening tests
- 7.111 Capacitive current test
- 7.112 Requirements for closing and opening tests of E2 class circuit breakers with rated voltage up to and including 40.5 kV
- 7.113 Noise level test
- 8 Factory Test
- 8.1 General Principles
- 8.2 Insulation test of main circuit
- 8.3 Testing of auxiliary and control circuits
- 8.4 Measurement of main circuit resistance
- 8.5 Sealing test
- 8.6 Design inspection and appearance inspection
- 8.101 Mechanical operation test
- 9 Guidelines for selection of circuit breakers
- 9.101 General
- 9.102 Selection of rated values under operating conditions
- 9.103 Selection of ratings under fault conditions
- 9.104 Selection of electrical life

- 9.105 Selection of capacitive load switching
- 10 Documents to be provided with enquiries, tenders and orders
 - 10.1 General
 - 10.2 Information provided with enquiries and orders
 - 10.3 Information provided with the tender documents
- 11 Rules for transportation, storage, installation, operation and maintenance
 - 11.1 General
 - 11.2 Conditions during transportation, storage and installation
 - 11.3 Installation
 - 11.4 Operation
 - 11.5 Maintenance
 - 11.101 Resistors and Capacitors
- 12 Safety
- 13 Impact of products on the environment
- Appendix A (Normative) Tolerances of test parameters during the test
- Appendix B (Normative) Type test records and reports
 - B.1 Data and results to be recorded
 - B.2 Contents of type test report
- Appendix C (Normative) Use of mechanical properties and related requirements
- Appendix D (Normative) Requirements for closing and opening test procedures for metal-enclosed circuit breakers and dead-shell circuit breakers
 - D.1 General
 - D.2 Reduced number of closing and breaking units for testing
 - D.3 Test of single pole in one enclosure
 - D.4 Test of three poles in one enclosure
- Appendix E (Normative) Requirements for circuit breakers with disconnecting resistors
 - E.1 General
 - E.2 Opening and closing performance verification
 - E.3 Resistor connection time
 - E.4 Current carrying performance
 - E.5 Insulation performance
 - E.6 Mechanical properties
 - E.7 Requirements for the technical specifications of disconnecting resistors
 - E.8 Example of recovery voltage waveform
- Appendix F (Normative) Method for determining expected TRV