

ICS 27.160
CCS K 83



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 20514-2006

**Photovoltaic systems -- Power conditioners -- Procedure for
measuring efficiency**

光伏系统功率调节器效率测量程序

(English Translation)

Issued on: August 25, 2006

Implemented on: February 1, 2007

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China, Standardization
Administration of the People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard provides an independent and grid-connected PV power conditioner system efficiency measurement method, in which the power output of the regulator is a certain frequency stability is stable AC voltage or DC voltage. This efficiency is input at the factory by directly measuring the magnitude of the output power calculated. This is also applicable to the case including the isolation transformer.

Document data

International classification (ICS): 27.160.

Chinese classification (CCS): K83.

Estimated length of the Chinese original: 17,173 words.

Adopted international standard: IEC 61683-1999, IDT.

Standards quoted by this document

IEC 60146-1-1-1991