

ICS 29.120.30

CCS K 30



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 20636-2006

**Connecting device -- Electrical cooper conductors -- Safety
requirements for screw-type and screwless-type clamping units
Particular requirements for conductors above 35mm² up to 300mm²**

连接器件 电气铜导线 螺纹型和非螺纹型夹紧件的安全要求 适用于35mm²以上至
300mm²导线的特殊要求

(English Translation)

Issued on: November 8, 2006

Implemented on: April 1, 2007

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China, Standardization
Administration of the People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard applies to devices independently or as a single -piece threaded parts and non- contact pattern type clamping units. Clamps for connecting the cross-sectional area of 35mm² to 300mm² stranded over a hard and/or soft Electrical copper conductors with a rated AC voltage is not greater than 1000V, the frequency is not greater than 1000Hz and rated DC voltage not exceeding 1500V.

Document data

International classification (ICS): 29.120.30.

Chinese classification (CCS): K30.

Estimated length of the Chinese original: 16,183 words.

Adopted international standard: IEC 60999-2-2003, IDT.

Standards quoted by this document

GB/T 3956-1997; GB 17464-1998; IEC 60999-1-1999