

ICS 71.040.40

CCS G 76



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 20780-2006

**Industrial circulating cooling water -- Determination of
carbonate alkalinity**

工业循环冷却水 碳酸盐碱度的测定

(English Translation)

Issued on: December 29, 2006

Implemented on: June 1, 2007

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People's Republic of China, Standardization
Administration of the People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the method for measuring industrial circulating cooling water carbonate alkalinity. This standard applies to industrial circulating cooling water carbonate alkalinity measured in the range of 0.01mmol/L ~ 4mmol/L of. Also applies to drinking water, Determination of carbonate alkalinity in natural waters. For high carbonate alkalinity of water samples, the method of analysis can be diluted.

Document data

International classification (ICS): 71.040.40.

Chinese classification (CCS): G76.

Estimated length of the Chinese original: 6,617 words.

Adopted international standard: ISO 9963-2-1994, MOD.

Standards quoted by this document

GB/T 601; GB/T 603; GB/T 6682