

ICS 27.100
CCS K 52



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 21426-2026

Replacing GB/T 21426-2008

**Special environmental conditions - Requirements for internal
combustion engine power stations on plateaus**

特殊环境条件 高原对内燃机电站的要求

Issued on: January 28, 2026

Implemented on: August 1, 2026

**Issued by: State Administration for Market Regulation;
Standardization Administration of the PRC**

Table of Contents

1.Scope	1
2 Normative References	1
3.Terms and Definitions	1
4 Requirements	2
4.1 General Rules	2
4.2 Environmental Conditions	2
4.3 Parameter	2
4.4 Types and Calibration of Rated Power	7
4.5 Structure and Design	8
4.6 Protection of high-temperature components	9
4.7 Startup Requirements	9
4.8 Temperature rise	9
4.9 Vibration	9
4.10 Noise	11
4.11 Insulation System	11
4.12 Insulation resistance	11
4.13 Withstand voltage	12
4.14 Electrical Specifications	12
4.15 Voltage Changes in Hot and Cold States	13
4.16 Appearance quality	14
4.17 Completeness	14
4.18 Phase Sequence	14
4.19 Illuminance	15
4.20 Indicator Device	15
4.21 Braking	15
4.22 Security	15
4.23 Protective Measures	15
4.24 Operating Mode	16
4.25 Radio Interference	16
4.26 Concentration of hazardous substances	16
4.27 Smoke opacity	16
4.30 Reliability and Maintainability	16

5. Test Rule	16
5.1 Test Classification	16
5.2 Test Conditions	17
5.3 Test Instruments and Meters	17
5.4 Test Item	17
6. Test Methods	20
6.1 Insulation resistance measurement	20
6.2 Withstand voltage test	20
6.3 Visual Inspection	20
6.4 Marking and Packaging Inspection	20
6.5 Completeness Inspection	20
6.6 Quality Measurement	20
6.7 External Dimension Measurement	20
6.8 Room Temperature Start-up Performance Check	21
6.9 Low Temperature Start-up Measures Inspection	21
6.10 Phase sequence check	21
6.11 Illuminance Check	21
6.12 Control panel indicator device inspection	21
6.13 Vehicle Braking Performance Inspection	21
6.14 Parking brake performance check	21
6.15 Inspection of protective devices (or measures)	21
6.16 High Temperature Protection Inspection	21
6.17 Functional check of manual emergency stop device	21
6.18 Insulation monitoring device inspection	21
6.19 Grounding Resistance Measurement	21
6.20 Short-circuit protection function check	21
6.21 Overload protection function check	21
6.22 Overvoltage protection function check	22
6.23 Undervoltage protection function check	22
6.24 Over-frequency protection function check	22
6.26 Underfrequency protection function check	22
6.26 Overheat protection function check	22
6.27 Low oil pressure protection function check	22
6.28 Overspeed protection function check	22
6.29 Reverse power protection function check	22

6.30 Frequency drop measurement	22
6.31 Steady-state frequency band measurement	22
6.32 Transient frequency deviation (relative to the initial frequency) and transient frequency deviation (relative to the rated frequency), respectively increased by (-) according to the load. And load reduction () and frequency recovery time measurement	22
6.33 Steady-state voltage deviation measurement	22
6.34 Voltage Unbalance Measurement	22
6.35 Measurement of relative voltage setting drop range and relative voltage setting rise range	22
6.36 Transient voltage deviation and voltage recovery time, measured separately for load increase (-) and load decrease ()	23
6.37 Voltage Modulation Measurement	23
6.38 Transient Characteristic Measurement	23
6.39 Check the ability to directly start the motor	23
6.40 Check for voltage changes under hot and cold conditions	23
6.41 Measurement of line voltage deviation under unbalanced load	23
6.42 Three-phase voltage phase shift measurement	23
6.43 Measurement of sinusoidal distortion rate of line voltage waveform	23
6.44 Measurement of Total Harmonic Content of Phase Voltage	23
6.45 Voltage Deviation Coefficient Measurement	23
6.46 Measurement of Frequency Modulation Amount and Frequency Modulation Rate ...	23
6.47 Measurement of Frequency Drift Amount and Frequency Drift Rate	23
6.48 Continuous operation test	23
6.49 Temperature rise measurement	23
6.50 Current stability measurement	24
6.51 Voltage regulation accuracy measurement	24
6.52 Pulsating Voltage Measurement	24
6.53 Fuel Consumption Rate Measurement	24
6.54 Vibration value measurement	24
6.55 Noise level measurement	24
6.56 Conducted Interference Measurement	24
6.57 Radiated Interference Measurement	24
6.58 Measurement of Hazardous Substance Concentration	24
6.59 smoke opacity measured	24
6.60 High Temperature Test	24
6.61 Low Temperature Test	24

6.62 Damp heat test	24
6.63 Rain test	24
6.64 Inclined Operation Test.....	25
6.65 Driving test	25
6.66 Transport Test.....	25
6.67 Reliability and Maintainability Tests	25
6.68 Solar Radiation Test	25
6.69 Dust Test	25
7. Marking, Packaging, Transportation and Storage	25
7.1 Mark	25
7.2 Packaging	26
7.3 Transportation	26
30 References	31

Foreword

This document complies with the provisions of GB/T 1.1-2020 "Standardization Work Guidelines Part

1. Structure and Drafting Rules of Standardization Documents". Drafting. This document replaces GB/T 21426-2008 "Requirements for Internal Combustion Engine Power Stations in High-Altitude Areas under Special Environmental Conditions", and is consistent with GB/T 21426- Compared to.2008, aside from structural adjustments and editorial changes, the main technical changes are as follows:

- The scope has been changed (see Chapter 1, Chapter 1 of the.2008 edition);
- The term "internal combustion engine power station system" has been added (see 3.1);
- The terms "high-altitude internal combustion engine power plant" and "standard baseline environmental conditions" have been removed (see 3.2 in the.2008 edition);
- Added requirements regarding "specified output power conditions" (see 4.2.1,.2008 version 4.2.1);
- The requirements for "Ambient Temperature Limits" have been revised (see 4.2.2,.2008 version 4.2.2);
- The requirements for "parameters" have been changed (see 4.3,.2008 version 4.3);
- The requirements for "Rated Power Types and Calibration" have been revised (see