

ICS 17.220.20

CCS N23



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 22264.7-2022

Replacing GB/T 22264.7-2008

**Mounted digital display electric measuring instruments - Part 7:
Special requirements for multi-function instruments**

安装式数字显示电测量仪表 第7部分：多功能仪表的特殊要求

Issued on: December 30, 2022

Implemented on: July 1, 2023

**Issued by: State Administration for Market Regulation;
Standardization Administration of China**

Table of Contents

1 Scope	1
2 Normative references	1
3 Terms and Definitions	1
4.1 Category	1
4.2 Classification	2
4.3 Compliance with the requirements of this document	2
5 Technical requirements	2
5.1 Standard power value	2
5.2 Reference conditions and basic errors	2
5.3 Nominal service range and change	2
5.4 Security requirements	3
5.5 Electrical requirements	3
5.6 Accuracy performance requirements	4
5.7 Electromagnetic Compatibility	4
5.8 Structural requirements	4
5.10 Reliability	4
5.11 Special functions	4
6 Information, general signs and symbols	5
6.1 Information	5
6.2 Signs, compliance and their location	5
6.3 Marking of nominal service range and reference value or reference range	5
6.4 Signs and symbols of terminals	5
7 Inspection rules	5
2 Table A.1 Test items and recommended sequence	6

Foreword

This document is in accordance with the provisions of GB/T 1.1-2020 "Guidelines for Standardization Work Part

1. Structure and Drafting Rules for Standardization Documents" drafting. This document is part 7 of GB/T 22264 "Mounted Digital Display Electrical Measuring Instruments". GB/T 22264 has issued the following part.

1. Definitions and general requirements;
2. Special requirements for ammeters and voltmeters;
3. Special requirements for power meters and reactive power meters;
4. Special requirements for frequency tables;
5. Particular requirements for phase meters and power factor meters;
6. Special requirements for insulation resistance meters;
7. Special requirements for multi-function instruments;
8. Test methods. This document replaces GB/T 22264.7-2008 "Mounted digital display electrical measuring instruments - Part 7. Special requirements for multi-function instruments". Compared with GB/T 22264.7-2008, except for structural adjustment and editorial changes, the main technical changes are as follows:
 - Changed the scope and added "This document is applicable to newly manufactured DC 750V and AC 690V and below, the nominal frequency is Installed digital display electrical measuring multifunctional instrument for measuring various electrical parameters in 50Hz or 60Hz power distribution system, also applicable For the digital display part of the electrical measuring multifunction instrument with analog/digital dual display (see Chapter 1, Chapter 1 of the.2008 edition);
 - Increased the standard power value (see 5.1);
 - Increased the nominal use range limits and allowable changes in Table 1 (see 5.3.1);

1 Scope

GB/T 22264.7-2022 is the Chinese national standard on mounted digital display electric measuring instruments - part 7: special requirements for multi-function instruments, in the field of metrology and measurement. The /T suffix marks it as a recommended standard: it is not compulsory by itself, but it becomes binding as soon as a contract, a tender or a customer specification calls it up - which in practice is how most foreign buyers meet it. It was issued on 30 December 2022 by the State Administration for Market Regulation; Standardization Administration of China, and has been in force since 1 July 2023.

Classification: ICS 17.220.20, CCS N23. This page is published from the official record of the standard held by the Chinese standards administration: the identification, the dates, the classification and the issuing body are taken from there. The clause text, the tables and the numeric limits are in the document itself, which is delivered complete in English translation.

This document specifies the product classification, classification and compliance, technical requirements, information, general Signs and symbols, inspection rules, and packaging,

storage and transportation. This document applies to newly manufactured power distribution systems below 750V DC and 690V AC with a nominal frequency of 50Hz or 60Hz. It is an installed digital display electrical measurement multifunctional instrument for measuring various electrical parameters in the system, and it is also suitable for electrical measurement multifunctional instruments with analog/digital dual display. The digital display part of the function meter. This document does not apply to.

- Multifunctional instruments with direct acting analog indication;
- Portable digital display multi-function instrument;
- Another national standard (or industry standard) special-purpose multifunctional instrument.

2 Normative references

The contents of the following documents constitute the essential provisions of this document through normative references in the text. Among them, dated references For documents, only the version corresponding to the date is applicable to this document; for undated reference documents, the latest version (including all amendments) is applicable to this document.

GB/T 22264.1-2022 Mounted digital display electrical measuring instruments Part

3 Terms and Definitions

GB/T 22264.1-2022, GB/T 22264.2-2022, GB/T 22264.3-2022, GB/T 22264.4-2022, The terms and definitions defined in GB/T 22264.5-2022 and GB/T 22264.6-2022 apply to this document.

4 Product classification, classification and conformity

4.1 Classification It shall comply with the provisions in

4.1 of GB/T 22264.1-2022, and the specific classification of each function shall comply with GB/T 22264.2-2022~ The provisions of

4.1 in GB/T 22264.6-2022.

5 Special requirements for phase meters and power factor meters

GB/T 22264.6-2022 Mounted digital display electrical measuring instruments Part