

ICS 29.080.99

CCS K 49



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 22389-2023

Replacing GB/T 22389-2008

**Metal-oxide surge arresters without gaps for HVDC converter
stations**

(English Translation)

Issued on: December 28, 2023

Implemented on: April 1, 2024

**Issued by: State Administration for Market Regulation, China National
Standardization Administration**

Table of Contents

Preface	
1 Scope	
2 Normative references	
3 Terms and Definitions	
4 Typical HVDC converter station schematic diagram, arrester type, installation location and operating voltage	
5 Logo and classification	
5.1 Lightning arrester marking	
5.2 Lightning arrester classification	
6 Operating conditions	
6.1 Normal operating conditions	13
6.2 Abnormal operating conditions	
7 Technical requirements	
7.1 Insulation resistance	
7.2 Reference voltage	
7.3 Residual pressure	
7.4 Partial discharge	15
7.5 Sealing performance	15
7.6 Current distribution	
7.7 Long-term stability	15
7.8 Repeated charge transfer tolerance	
7.9 Action load test	
7.10 Short circuit performance	15
7.11 Internal voltage equalizing component	
7.12 Mechanical load	
7.13 Electromagnetic compatibility	16
7.14 End of life	16
7.15 Continuous current	
7.16 Leakage current at 0.75 times DC reference voltage	
7.17 High current surge withstand	17
7.18 Contamination resistance	17
7.19 Appearance requirements for composite jackets	

- 7.20 Weathering aging test
- 7.21 GIS arrester housing requirements
- 7.22 Rated density (rated pressure) and minimum operating density (minimum operating pressure) of GIS arrester insulating gas
- 7.23 GIS arrester insulating gas requirements
- 7.24 GIS arrester transportation vibration performance
- 7.25 Packaging, transportation and storage 18
- 8 Test requirements
- 8.1 Measuring equipment and accuracy 18
- 8.2 Test sample
- 9 Type test (design test)
- 9.1 General
- 9.2 Insulation withstand test
- 9.3 Short circuit test
- 9.4 Partial discharge test
- 9.5 Mechanical load test
- 9.6 Environmental test
- 9.7 Weathering aging test
- 9.8 Sealing test
- 9.9 Radio interference voltage (RIV) test
- 9.10 Residual pressure test
- 9.11 Long-term stability test
- 9.12 Repeated charge transfer test
- 9.13 Heat dissipation characteristic test
- 9.14 Action load test
- 9.15 Internal component insulation withstand test
- 9.16 Test of internal voltage equalizing components
- 9.17 Power frequency reference voltage test
- 9.18 DC reference voltage test
- 9.19 Leakage current test at 0.75 times DC reference voltage
- 9.20 Large current impulse withstand test
- 9.21 Unified creepage distance inspection
- 9.22 Current distribution test
- 9.23 Continuous current test
- 9.24 Appearance inspection of composite jacket

10 Routine tests, acceptance tests, sampling tests and periodic tests

10.1 Routine testing

10.2 Acceptance test

10.3 Sampling test

10.4 Periodic testing

11 Test requirements for different types of arresters

11.1 General

11.2 Valve arrester (V)

11.3 Bridge arresters and HV and LV converter arresters (B, CH, CL)

11.4 Converter arrester (C)

11.5 Midpoint DC bus arrester, bridge midpoint arrester and inter-converter arrester (M, MH, ML, CM)

11.6 Converter DC bus arrester (CB)

11.7 DC bus and DC line/cable arresters (DB, DL/DC)

11.8 Neutral bus arrester (EB, E1, E)

11.9 DC and AC filter arresters (FA, FD)

11.10 Ground pole and metal return arrester (EL, EM)

11.11 Smoothing reactor and arrester (DR)

11.12 Capacitor arrester (CC)

11.13 Transformer valve side arrester (T)

Appendix A (informative) This document is compared with the regulation number of IEC 60099-9:2014

Appendix B (informative) The main technical differences between this document and IEC 60099-9:2014 and their reasons

Appendix C (Normative) Mechanical Test

Appendix D (informative) Packaging, transportation and storage

Appendix E (Normative) Thermal Equivalence Test

Appendix F (Normative) Thermal stability test starting temperature

Appendix G (informative) Configuration of different loops

Appendix H (informative) Typical arrester parameters for DC projects

Reference

Figure 1 Single-pole schematic diagram of a typical converter station with dual 12-pulse converters

Figure 2 Single-pole schematic diagram of a typical converter station with a single 12-pulse converter

Figure 3 Schematic diagram of a typical capacitor-commutated converter (CCC) with dual 12-pulse converter 10

Figure 4 Typical continuous operating voltages of different types of arresters in the low-frequency model (see Figures 1 to 3 for specific locations, base frequency 50Hz)

Figure 5 Typical continuous operating voltages of different types of arresters in the high-frequency model (see Figures 1 to 3 for specific locations, base frequency 50Hz)

Figure 6 Thermal engine test

Figure 7 Arrangement of thermal engine test and bending load direction

Figure 8 Water immersion test

Figure 9 Accelerated aging test method with voltage polarity reversal a)

Figure 10 Operating voltage waveform of valve arrester (V) (rectified operation), PCOV and CCOV

Figure 11 Waveforms of continuous operating voltage of bridge arrester, DCOV, PCOV and CCOV

Figure 12 Relative duration of voltage exceeding a certain value

Figure C:1 Bending moment test of multi-element arrester

Figure C:2 Definition of mechanical load

Figure C:3 Arrester components

Figure C:4 Dimensions of arrester

Figure C:5 Bending load test procedure flow chart

Figure G:1 Schematic diagram of CSCC converter station with dual 12-pulse converters 76

Figure G:2 Schematic diagram of back-to-back converter station with dual 12-pulse converters 77

Table 1 Partial discharge test voltage value

Table 2 Routine tests

Table 3 Acceptance test

Table 4 Sampling test

Table 5 Periodic test

Table 6 Type test

Table 7 Type test

Table A:1 Comparison between this document and the regulation numbers of IEC 60099-9:2014

Table B:1 Main technical differences between this document and IEC 60099-9:2014 and their reasons

Table H:1 Typical $\pm 1100\text{kV}$ UHV DC engineering arrester parameters 78

Table H:2 Typical $\pm 800\text{kV}$ UHV DC engineering arrester parameters 78

Table H:3 Typical $\pm 500\text{kV}$ high-voltage DC engineering arrester parameters 79