

ICS 29.080.10

CCS K 48



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 24623-2009

Radio interference test on high-voltage insulators

高压绝缘子无线电干扰试验

(English Translation)

Issued on: November 30, 2009

Implemented on: April 1, 2010

Issued by: Standardization Administration of China

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the insulator in a clean, dry laboratory on Radio Interference (RI) test procedures, measurement frequency is 0.5MHz or 1MHz, or 0.5MHz ~ 2MHz within a certain frequency. Operation, the insulator element radio interference characteristics may be due to environmental conditions, particularly humidity and contamination rainfall and other conditions vary. Taking into account the range of environmental conditions simulated rain reproducible test conditions specified is not feasible, therefore, the standard only provides a clean and dry insulators tests.

Document data

International classification (ICS): 29.080.10.

Chinese classification (CCS): K48.

Estimated length of the Chinese original: 12,165 words.

Adopted international standard: IEC 60437-1997, MOD.

Standards quoted by this document

GB/T 1001.1-2003; GB/T 4109-2008; GB/T 6113.101-2008; GB/T 8287.1-2008; GB/T 16927.1-1997; IEC 60383-2-1993; CISPR 18-2-1986; GB/T 2900.8