

CCS K 74



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 30104.303-2021

**Digital addressable lighting interface - Part 303: Particular
requirements - Input devices - Occupancy sensor**

Issued on: December 31, 2021

Implemented on: July 1, 2022

**Issued by: State Administration for Market Regulation, China National
Standardization Administration**

Table of Contents

foreword

Introduction

1 Scope

2 Normative references

3 Terms and Definitions

foreword

This document is in accordance with the provisions of GB/T 1:1-2020 "Guidelines for Standardization Work Part 1: Structure and Drafting Rules of Standardization Documents"

drafted:

This document is part 303 of GB/T 30104 "Digital Addressable Lighting Interface": GB/T 30104 has released the following parts:

- Part 101: General requirements for system components;
- Part 102: General requirements for control devices;
- Part 103: General requirements for control equipment;
- Part:201: Particular requirements for control gear fluorescent lamps (equipment type 0);
- Part 202: Particular requirements for control gear Self-contained emergency lighting (equipment type 1);
- Part 203: Particular requirements for control devices for discharge lamps (other than fluorescent lamps) (equipment type 2);
- Part 204: Particular requirements for control gear low-voltage tungsten halogen lamps (equipment type 3);
- Part 205: Particular requirements for control gear incandescent lamp supply voltage controllers (equipment type 4);
- Part 206: Particular requirements for control gear digital signals into DC voltage (equipment type 5);
- Part 207: Particular requirements for control gear LED modules (equipment type 6);
- Part 208: Particular requirements for control gear switch functions (equipment type 7);
- Part 209: Particular requirements for control devices Color control (equipment type 8);

- Part 301: Special requirements for input device buttons;
- Part 302: Special requirements for input devices Absolute input devices;
- Part 303: Special requirements for input device occupancy sensors;
- Part 304: Special requirements for input device light sensors:

This document uses the translation method equivalent to IEC 62386-303:2017 "Digital Addressable Lighting Interface Part 303: Special Requirements

Input Device Occupancy Sensor":

The Chinese documents that have a consistent correspondence with the international documents of normative references in this document are as follows:

---GB/T 30104:101-2021 Digital Addressable Lighting Interface Part 101: General Requirements System Components (IEC 62386-

101:2014, IDT)

---GB/T 30104:103-2017 Digital Addressable Lighting Interface Part 103: General Requirements Control Equipment (IEC 62386-

103:2014, IDT)

Please note that some content of this document may be patented: The issuing agency of this document assumes no responsibility for identifying patents:

Introduction

GB/T 30104 aims to standardize the digital addressable lighting interface and is intended to consist of the following parts:

Part 103 specifies the general requirements for control equipment:

It is a special requirement to regulate the control device for a specific type of light source:

It is a special requirement that regulates various types of input devices:

GB/T 30104 is divided into several parts and published as a series of standards, and specific provisions are made for each type of equipment: The purpose is to facilitate the standardization of standards:

use and maintenance:

This document will be used concurrently with GB/T 30104:101 and GB/T 30104:103:

The structure of the series of standards is shown in Figure 1 as follows:

Figure 1 Overview of GB/T 30104

The scope of this clause and the order in which the tests are performed: Other sections also include additional requirements when necessary:

except:

The standardization of the control interface of the control equipment is to realize the compatible coexistence and multi-master operation between the electronic control device and the lighting control equipment,

This system is at a lower level than the building management system: This document describes a method for implementing an occupancy sensor:

Unless otherwise stated, numbers used in this document are in decimal: Hexadecimal numbers are in the format 0xVV, where VV is the number

"Any value":

Use the following typographical expressions:

Variable: "variable name" or "variable name[3:0]", only for the 3rd to 0th bits of "variable name":

Range of values: [min,max]:

Directive: "directive-name":

Digital Addressable Lighting Interface

Part 303: Special requirements for input devices

Occupancy sensor

1 Scope

This document specifies a bus system controlled by digital signals for electronic lighting equipment that complies with IEC 61347 (all parts

points) requirements, and have a DC power supply:

This document only applies to GB/T 30104:103-2017 and IEC 62386-103:2014/Amd1:2018 by movement or presence

The sensing transmits occupancy information to the input device of the lighting control system:

Note: Testing requirements for individual products during production are not included:

2 Normative references

The contents of the following documents constitute essential provisions of this document through normative references in the text: Among them, dated citations

documents, only the version corresponding to that date applies to this document; for undated references, the latest edition (including all amendments) applies to this document:

GB/T 30104:103-2017 Digital Addressable Lighting Interface Part 103: General Requirements Control Equipment (IEC 62386-103:2014, IDT)

IEC 62386-101 Interfaces for digitally addressable lighting - Part 101: General requirements for system components (Digitaladdressable lightinginterface-Part 101:Generalrequirements-Systemcomponents)

IEC 62386-103 Interfaces for digitally addressable lighting - Part 103: General requirements for control equipment (Digitaladdressable lightinginterface-Part 103:Generalrequirements-Controldevices)

IEC 62386-103:2014/Amd1:2018 Digital addressable lighting interfaces Part 103: General requirements for control equipment

(Digitaladdressablelightinginterface-Part 103:Generalrequirements-Controldevices)

IEC 62386-333 Digitally addressable lighting interfaces Part 333: Particular requirements for control equipment Manual configuration [Digitalad-

dressablelightinginterface-Part 333:Particularrequirementsforcontroldevices-Manualconfiguration(featuretype33)]

3 Terms and Definitions

Terms and definitions defined in IEC 62386-101 and IEC 62386-103 and the following terms and definitions apply to this document:

3:1

instance instance

The motion of the input device or the presence of the input signal processing module:

[Source: GB/T 30104:101-2021, 3:29, with modifications]

3:2

motion sensor motionsensor

Instances based only on motion detection, motion means occupancy, and no movement for a certain time is vacancy: