

ICS 19.080

CCS K 40



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 311.6-2005

Replacing GB/T 311.6-1983

Voltage measurement by means of standard air gaps

高电压测量标准空气间隙

(English Translation)

Issued on: February 6, 2005

Implemented on: December 1, 2005

**Issued by: General Administration of Quality Supervision, Inspection and
Quarantine of the People Republic of China, China National
Standardization Administration Committee**

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard specifies the air gap measure voltage using standard manufacturing and use, and for the following peak voltage measurements: a) frequency AC voltage, b) full-wave lightning impulse voltage, c) operation impulse voltage, d) DC voltage. Production and use in accordance with the standard air gap measurement system is mainly used for high performance test.

Document data

International classification (ICS): 19.080.

Chinese classification (CCS): K40.

Estimated length of the Chinese original: 22,252 words.

Adopted international standard: IEC 60052-2002, IDT.

Supersedes the earlier edition GB/T 311.6-1983.