

ICS 03.220.40

CCS R 45



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 36028.2-2025

Replacing GB/T 36028.2-2018

**Technical conditions for shore-to-ship power supply systems -
Part 2: Low voltage connection**

靠港船舶岸电系统技术条件 第2部分：低压供电

Issued on: December 2, 2025

Implemented on: July 1, 2026

**Issued by: State Administration for Market Regulation;
Standardization Administration of the PRC**

Table of Contents

- 1 Scope
- 2 Normative references
- 3 Terms and Definitions
- 4 System Composition
- 5 General Provisions
- 6 Technical Specifications
- 11 Dry-type Transformers
- 14 Reference

Foreword

This document complies with the provisions of GB/T 1.1-2020 "Standardization Work Guidelines Part

1. Structure and Drafting Rules of Standardization Documents". Drafting. This document is Part 2 of GB/T 36028 "Technical Conditions for Shore Power Systems of Ships at Port". GB/T 36028 has published the following... part.

1. High-voltage power supply;

2. Low-voltage power supply. This document replaces GB/T 36028.2-2018 "Technical Conditions for Shore Power Systems of Ships at Port - Part

2. Low-Voltage Power Supply", and is consistent with... Compared with GB/T 36028.2-2018, apart from structural adjustments and editorial changes, the main technical changes are as follows:

a) The scope of application has been changed (see Chapter 1, Chapter 1 of the 2018 edition);

b) The terms "low-voltage power supply" and "power outage switching" and their definitions (see

3.2 in the 2018 edition) have been deleted, and the term "ships berthing in port" has been added. "Ship-to-shore power system", "low-voltage shore power supply", "cable management device" and "low-voltage transfer device" and their definitions (see 3.1~3.4);

c) The composition of the shore power system for vessels berthing at port has been changed (see 4.1, 2018 version 4.1);

d) The power supply method has been removed (see section

4.2 of the 2018 version);

e) Requirements for shore power frequency power supply and shore power frequency converter configuration have been added (see 4.2);

f) The requirements for work environment conditions have been changed (see 5.1, 2018 version 5.1);

g) Requirements for shore power systems have been changed (see 5.2, 2018 version 5.2);

1 Scope

GB/T 36028.2-2025 is the Chinese national standard covering the low voltage shore connection for the smaller vessels - inland barges, tugs and fishing boats, where the currents are high for the power delivered and the cable and connector are handled by the crew rather than by a gantry. It replaces GB/T 36028.2-2018. It was issued on 2 December 2025 and has been in force since 1 July 2026, replacing GB/T 36028.2-2018. The document is under the responsibility of the Ministry of Transport. This page is published from the official record of the 2025 edition; the clause text of a standard this recent is not yet in circulation, and the figures, limits and tables it contains are those of the document itself, delivered in full with the English translation.

This document specifies the system composition, general provisions, and technical specifications for low-voltage power supply to shore power systems (hereinafter referred to as "shore power systems") on vessels berthed in port. and experimental methods. This document applies to the design, development, and application of shore power systems for ships berthing in ports with a voltage not exceeding 1000V AC.

2 Normative references

The contents of the following documents, through normative references within the text, constitute essential provisions of this document. Dated citations are not included. For references to documents, only the version corresponding to that date applies to this document; for undated references, the latest version (including all amendments) applies. This document.

GB/T 1094.11 Power Transformers - Part

3 Terms and Definitions

The following terms and definitions apply to this document.

3.1 Facilities that provide electrical power to ships from the port while they are berthed.

3.2 Low-voltage shore-to-ship power During the vessel's berthing period, provide dedicated low-voltage power supply equipment suitable for the vessel's voltage and frequency.

Note. The voltage of low-voltage shore power supply shall not exceed AC 1000V.

11 Dry-type Transformers

GB/T 4208-2017 Degrees of protection provided by enclosures (IP code)

GB/T 11918.5 Industrial plugs, sockets and couplers - Part

5.Plugs and sockets for low-voltage shore power connection systems (LVSC systems) Size compatibility and interchangeability requirements for marine connectors and marine input sockets

GB/T 12325 Power Quality - Supply Voltage Deviation

GB/T 12326 Power Quality - Voltage Fluctuations and Flicker

GB/T 14549 Power Quality - Harmonics in Public Power Grids

GB/T 15945 Power Quality - Frequency Deviation of Power Systems

GB/T 16934 Electricity Metering Cabinet

GB/T 36028.1 Technical conditions for shore power systems of ships in berth - Part