

ICS 29.240.01

CCS F 21



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 42151.6-2024

**Communication networks and systems for power utility automation -
Part 6: Configuration description language for communication in power
utility automation systems related to IEDs**

电力自动化通信网络和系统 第6部分：与智能电子设备相关的电力自动化系统通信配置描述语言

(English Translation)

Issued on: December 31, 2024

Implemented on: July 1, 2025

**Issued by: State Administration for Market Regulation, China National
Standardization Administration**

Table of Contents

Preface
Introduction
1 Scope
1.1 Overview
1.2 Namespaces and Versions
1.3 Code Component Distribution
2 Normative references
3 Terms and Definitions
4 Abbreviations
5 SCL's expected engineering process
5.1 General
5.2 SCL Range
5.3 Use of SCL in the Engineering Process
5.4 IED Modification
5.5 Data exchange between projects
6 SCL Object Model
6.1 General
6.2 Process Model
6.3 Product (IED) model
6.4 Communication System Model
6.5 Redundancy Modeling
6.6 Data Flow Modeling
7 SCL description file type
8 SCL language
8.1 Standardization Methods
8.2 Language Version and Compatibility
8.3 SCL Language Extensions
8.4 General structure
8.5 Object and Signal Naming
9 SCL Syntax Elements
9.1 Header
9.2 Process Description

9.3 IED Description	
9.4 Communication System Description	
9.5 Data Type Templates	
10 Tools and Project Engineering Permissions	
10.1 IED Configuration Tool	
10.2 System Configuration Tools	
10.3 Transfer of authority between projects	
Appendix A (Normative) SCL Syntax. XML Schema Definition	
A.1 Basic Types	
A.2 Substation syntax	
A.3 Data Type Templates	
A.4 IED capabilities and structure	
A.5 Communication subnet	
A.6 Main SCL	
Appendix B (informative) SCL enumeration 211 as defined in IEC 61850-7-3 and IEC 61850-7-4	
Appendix C (Informative) Syntax Extension Examples	
C.1 Extended syntax for drawing layout coordinates	
Appendix D (Informative) Example	
D.1 Example Specification	
D.2 Example of SCL file content	
Appendix E (Informative) SCL Syntax. Generic XML Schema Definition	
E.1 Overview	
E.2 Basic Types	
E.3 Substation syntax	
E.4 Data Type Templates	
E.5 IED Capabilities and Structure	
E.6 Communication subnet	
E.7 Main SCL	
Appendix F (Informative) XML Schema Definitions for SCL Variants	
Appendix G (Normative) SCL Implementation Conformance Statement (SICS)	
Appendix H (Informative) ExtRef Use Case	
Appendix I (Normative) SCL---Mixed Version Project	
I.1 Overview	
I.2 Demotion Rules	

I.3 Upgrade Rules

I.4 Mixed versions of Ed2 and Ed2.1 devices/SCT items

Reference

Foreword

This document is in accordance with the provisions of GB/T 1.1-2020 "Guidelines for standardization work Part 1: Structure and drafting rules for standardization documents" Drafting.

This document is Part 6 of GB/T 42151 "Electric Power Automation Communication Networks and Systems". GB/T 42151 has been published for the following part.

- Part 3: General requirements;
- Part 4: System and project management;
- Part 5: Communication requirements for functional and device models;
- Part 6: Communication configuration description language for power automation systems related to intelligent electronic devices;
- Part 7-1. Basic communication structure principles and models;
- Part 7-2. Basic information and communication structure Abstract Communication Service Interface (ACSI);
- Part 7-7. IEC 61850 related data model machine processable format for tools;
- Part 8-1. Specific Communication Service Mapping (SCSM) Mapping to MMS (ISO 9506-1 and ISO 9506-2) and ISO/IEC 8802-3.

This document is equivalent to IEC 61850-6:2018 "Electric power automation communication networks and systems Part 6: Related to intelligent electronic devices Communication Configuration Description Language for Electric Power Automation System.

Introduction

GB/T 42151 "Electric Power Automation Communication Network and System" aims to provide interoperability for all equipment in the electric power automation system.

The following parts are composed.

- Part 1: Introduction. The purpose is to introduce the overview of this document.
- Part 2: Terminology. The purpose is to list the terms and definitions used in this document.

--- Part 3: General requirements. The purpose is to introduce the overall requirements of communication networks, with an emphasis on quality requirements.

--- Part 4: System and project management. The purpose is to describe the requirements for system and project management processes and the requirements for engineering and testing Dedicated support tools required.

--- Part 5: Communication requirements for functions and device models. The purpose is to specify the communication requirements for various functions of the power automation system.

--- Part 6: Communication configuration description language for power automation systems related to intelligent electronic devices. The purpose is to exchange of intelligent electronic device capability descriptions in a way that allows for the exchange of power automation system capabilities between tools provided by different manufacturers describe.

--- Part 7: Basic communication structure of power automation system. The purpose is to define a hierarchical class model and the services provided by these classes.

services to enable communication between devices.

--- Part 8: Specific communication service mapping SCSM. The purpose is to provide substation control layer and bay layer and station control layer and Communication mapping between bay layers.

--- Part 9: Specific communication service mapping SCSM. The purpose is to provide substation bay layer and process layer and bay layer and Communication mapping between process layers.

--- Part 10: Conformance testing. The purpose is to specify the standard technology for implementing conformance testing and to use when proposing performance parameters specific measurement techniques.

This document is part of a set of definitions that describe in detail a hierarchical power automation communication architecture that provides abstract definitions of classes and services.

The definition is independent of a specific communication stack, implementation, or operating system.

This document specifies a description language for the configuration of intelligent electronic devices (IEDs) in power automation. This language is called system configuration description.

SCL is used to describe the IED configuration and communication system implemented in accordance with GB/T 42151.5-2022 and IEC 61850-7-x.

It can standardize the relationship between power automation systems and processes