

ICS 29.240

CCS F 20



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 45905.6-2025

**Electricity spot market operation - Part 6: Frequency regulation
capacity management**

电力现货市场运营 第6部分：调频容量管理

Issued on: August 1, 2025

Implemented on: February 1, 2026

**Issued by: State Administration for Market Regulation;
Standardization Administration of the PRC**

Table of Contents

Preface	III
Introduction	IV
1 Scope	1
2 Normative references	1
3 Terms and Definitions	1
4 General Requirements	1
5 FM capacity setting	1
6 Frequency Regulation Capacity Evaluation and Adjustment	3
Appendix A (Informative) Forecast Deviation Calculation Method	4
Appendix B (Informative) Historical Data Correction Method	6
Appendix C (Informative) Calculation Method for Frequency Regulation Capacity Adjustment	8
Reference	10

Foreword

This document is in accordance with the provisions of GB/T 1.1-2020 "Guidelines for standardization work Part 1: Structure and drafting rules for standardization documents" Drafting.

This document is Part 6 of GB/T 45905 "Electricity Spot Market Operation". GB/T 45905 has been published in the following parts.

- Part 1: Terminology;
- Part 2: Provincial technical support system;
- Part 3: Inter-provincial technical support system;
- Part 4: Load forecasting;
- Part 5: Calculation method for new energy participation in power balance;
- Part 6: Frequency modulation capacity management;
- Part 7: Spare capacity management;
- Part 8: Multi-cycle power and quantity balance calculation method;
- Part 9: Market power monitoring and mitigation;

- Part 10. Operational evaluation.

Please note that some of the contents of this document may involve patents. The issuing organization of this document does not assume the responsibility for identifying patents.

This document was proposed by the China Electricity Council.

This document is under the jurisdiction of the National Technical Committee for Standardization of Power Grid Operation and Control (SAC/TC446).

This document was drafted by: State Grid Corporation of China, State Grid Zhejiang Electric Power Co., Ltd., Zhejiang University, China Southern Power Grid Co., Ltd.

Company, State Grid Corporation of China East China Branch, State Grid Corporation of China Northwest Branch, State Grid Corporation of China Central China Branch, State Grid Corporation of China Co., Ltd. Southwest Branch, State Grid Jiangsu Electric Power Co., Ltd., State Grid Shandong Electric Power Company, State Grid Shanxi Electric Power Company, State Grid Gansu Electric Power Company Power Company, State Grid Sichuan Electric Power Company, China Electric Power Research Institute Co., Ltd., Nanrui Group Co., Ltd., Inner Mongolia Electric Power (Group) Limited Liability Company, Beijing Power Exchange Co., Ltd.

The main drafters of this document are: Sun Dayan, Luo Zhiqiang, Wang Chao, Xu Lizhong, Tang Qiwen, Ma Ke, Luo Renjie, Zhou Ziqing, Tan Chao, Wang Delin, Xiang Zhongming, Wu Huahua, Chang Naichao, Guan Li, Cui Da, Wang Yanan, Dong Shimeng, Lin Sunben, Sun Ke, Shen Shaofei, Zhang Zhi, Deng Hui, Li Zhiyi, Ma Xiang, Zhang Xiaobai, Zhu Minjian, Li Hongbo, Liu Qixing, Liu Xianzhuo, Teng Xiaobi, Chen Qianchang, Yang Zheng, Zeng Xingxing, Guo Tao, Li Yifeng, Li Shan, Chang Liangliang, Cui Jian, Tang Lun.

Introduction

In order to further implement the national decision-making arrangements for deepening power system reform and accelerating the construction of a new power system, and to support the high-quality development of the power spot market, This series of standard.

GB/T 45905 "Electricity Spot Market Operation" covers terminology, provincial technical support system, inter-provincial technical support system, load forecasting, new energy Source participation power balance calculation method, frequency regulation capacity management, reserve capacity management, multi-cycle power balance calculation method, market power monitoring and It comprehensively covers all aspects of electricity spot market operation, including mitigation and operational assessment. GB/T 45905 is planned to consist of 10 parts.

- Part 1: Terminology. The purpose is to standardize the terms and definitions related to electricity spot market operation and grid operation, to provide a standardized and high-level Provide guidance for the effective construction and operation of electricity spot

markets.

- Part 2: Provincial technical support system. The purpose is to standardize the system architecture, functional requirements, performance of the provincial technical support system requirements, data interaction, reliability assurance, security protection and other technical requirements, as a provincial technical support system design, development, construction and Basis for operation.
- Part 3: Inter-provincial technical support system. The purpose is to standardize the system architecture, functional requirements, performance of the inter-provincial technical support system requirements, data interaction, reliability assurance, security protection and other technical requirements, as the provincial technical support system design, development, construction and Basis for operation.
- Part 4: Load Forecasting. The purpose is to specify the basic technical requirements for load forecasting in the electricity spot market, which is used to guide the Market operators, business entities and power grid companies carry out short-term and ultra-short-term system load forecasting, bus load forecasting and Household load forecasting.
- Part 5: Calculation method for new energy participating in power balance. The purpose is to standardize the power spot market environment, wind power, photovoltaic power, etc.

Principles, calculation methods and basic data requirements for the participation of new energy in electricity balance at different scales.

- Part 6: Frequency Regulation Capacity Management. The purpose is to standardize the overall requirements and calculation methods for frequency regulation capacity setting in the spot market, clarify Determine the frequency regulation capacity evaluation and adjustment methods, improve the standardization of the frequency regulation market and the compliance operation level of the spot market, and guide provincial/regional The power grid carries out frequency regulation capacity management.
- Part 7: Spare capacity management. The purpose is to standardize spare capacity configuration, spare capacity mutual assistance, spare capacity recovery and other requirements.

Provide guidance to provincial/regional power grids on reserve capacity management.

- Part 8: Multi-cycle power and quantity balance calculation method. The purpose is to specify the basic requirements for multi-cycle power and quantity balance calculation.

The requirements, data requirements, calculation methods and conclusion analysis are used to guide provincial and above power grids in dispatching production organization and spot market operation.

Carry out multi-cycle (year, month, week, day) power and electricity balance work during the process.

- Part 9: Market power monitoring and mitigation. The purpose is to standardize the monitoring methods and mitigation of market power in provincial/regional electricity spot markets.

Mitigation measures provide guidance for market power monitoring and mitigation.

- Part 10. Operational evaluation. The purpose is to standardize the evaluation requirements, evaluation indicators, and evaluation of provincial/regional electricity spot market operations.

The evaluation methods are used to provide guidance for the operation evaluation of the electricity spot market.

Electricity spot market operations Part 6: Frequency Regulation Capacity Management

1 Scope

This document specifies the requirements for setting, evaluating and adjusting frequency regulation capacity in the electricity spot market.

This document applies to the setting, evaluation and adjustment of frequency regulation capacity in provincial/regional electricity spot markets.

2 Normative references

GB/T 15945-2008

GB/T 31464-2022

GB/T 45905.1

3 Terms and Definitions

The terms and definitions defined in GB/T 45905.1 apply to this document.

4 General Requirements

4.1 The frequency regulation capacity set by each provincial/regional power grid should cover the deviation and volatility of new energy and load forecasts in the future period, as well as the generation capacity.

System frequency modulation requirements caused by electrical deviations, etc.

Note. The future period refers to the time scales of days, months, seasons, and years selected by provincial/regional power grids based on their update cycles.

4.2 The frequency regulation capacity set by each provincial/regional power grid should be updated periodically, and the update cycle should be based on the load and new energy