

ICS 29.120.01;29.120.30
CCS K 30



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 47637.1-2026

**Direct current (DC) appliance couplers for information and
communication technology (ICT) equipment installed in data
centres and telecom central offices - Part 1: 2.6 kW system**

数据中心和电信中心机房安装的信息和通信技术（ICT）设备用直流器具耦合器
第1部分：2.6kW系统

(English Translation)

Issued on: July 2, 2026

Implemented on: February 1, 2027

Issued by: State Administration for Market Regulation

Table of Contents

Preface	
Introduction	
1 Scope	
2 Normative References	
3 Terms and Definitions	
4 General Requirements	
6 Standard Ratings	
7 Classification of appliance couplers	8.
8 Symbols	
9 Size and Interchangeability	
10 Protection against electric shock.	
11 Grounding measures	
12 Terminals and connectors	
13 Structure	
14 Insulation resistance and electrical strength	
15 Force required to insert and remove the connector.	
16 Operation of the contacts	
17 Heat resistance of the device coupler	
18 Breaking capacity	
19 Normal operation	
20 Temperature rise	
21 Flexible wires and their connections	20.
22 Mechanical strength	
23 Heat resistance and anti-aging properties	
24 Screws, current-carrying components and their connections	
26 Heat resistance, flame retardancy, and tracking resistance of insulating materials	29.
27 Rust prevention	
28 Electromagnetic compatibility (EMC) requirements	
Appendix A (Normative) Routine Tests for Electrical Accessories with Factory Wiring (Protection Against Electric Shock and Correct Polarity)	
Appendix B (Normative) Test Arrangement	
Appendix C (Informative) Selective Clamping Test	

Appendix D (Normative) Standard Loose-leaf and Gauges References

1 Scope 1

2 Normative References 1

3 Terms and Definitions

4 General Requirements 6

6 Standard Ratings 8

7. Classification of appliance couplers 8.

9 Size and Interchangeability

10. Protection against electric shock.

11 Grounding measures 11

12 Terminals and connectors 11

13 Structure 11

14 Insulation resistance and electrical strength 14

15. Force required to insert and remove the connector.

16 Operation of the contacts 16

17 Heat resistance of the device coupler

18 breaking capacity 17

19 Normal operation 18

20 Temperature rise 19

21. Flexible wires and their connections 20.

22 Mechanical strength 23

23 Heat resistance and anti-aging properties 25

24 Screws, current-carrying components and their connections 26

26.Heat resistance, flame retardancy, and tracking resistance of insulating materials 29.

27 Rust prevention 30

28 Electromagnetic compatibility (EMC) requirements 31

Appendix A (Normative) Routine Tests for Electrical Accessories with Factory Wiring
(Protection Against Electric Shock and Correct Polarity) 32

Appendix B (Normative) Test Arrangement 34

Appendix C (Informative) Selective Clamping Test 36

Appendix D (Normative) Standard Loose-leaf and Gauges 39

References 49

Figure 1.Intended application of the appliance coupler 3

Figure 2 Test apparatus for maximum pull-out force 16

Figure 3 Breaking capacity and normal operation test circuit diagram 18

Figure 4.Test apparatus for flexible cable fixing components 21

Figure 5 Bending test apparatus 22

Figure 6 Example 24 of tensile testing equipment

Figure C.1 Comparison connector 37 for clamping test

Figure C.2 Example of test equipment for connector clamping test 38

Figure D.1 Appliance Input Socket 40

Figure D.2 Connector 41

Figure D.3 Position of " " and "-" pins/sleeves 42

Figure D.5 is a gauge (Figure D.1) used to inspect the input sockets of appliances
conforming to standard loop 1.44

Figure D.6 is a GO gauge (Figure D.2) used to inspect standard hinge 2 connectors. 45

Figure D.7 Gauge 46 for checking the maximum pull-out force of the corresponding
appliance input socket

Figure D.8 Gauge 47 for checking the minimum pull-out force of the connector's "+" and "-"
sockets.

Figure D.9 Gauge 47 for checking the minimum pull-out force of the connector PE socket.

Figure D.10 Optional micro switch driver positioning area 48

Figure D.11 Minimum size of the switch cam. 48

Table 1.Relationship between rated power and nominal cross-sectional area of connectable copper wires.

Table 2 Maximum diameter of flexible wire 15

Table 3 Maximum and minimum pull-out force 15

Table 4.Experimental Flexible Cords and Conductors (Chapter 20) 19

Table 5.Types and nominal cross-sectional areas of flexible wires (20 ohms)

Table 6.Type 21 of flexible cable used for testing detachable connectors.

Table 7.Tension values applied in the transverse tensile test 24

Table 8 Test values of tensile force 25

Table 9.Torque applied during tightening and loosening tests 27

Table 10 Creepage Distance, Clearance, and Distance Through Insulating Sealant 28

Table B.1 Experimental Arrangement 34

Table D.1 Dimensions of contact gauges and non-contact gauges 43

This document complies with the provisions of GB/T 1.1-2020 "Standardization Work Guidelines Part 1: Structure and Drafting Rules of Standardization Documents".

Drafting.

This document is based on GB/T 47637 "DC Appliance Coupling for Information and Communication Technology (ICT) Equipment Installed in Data Centers and Telecommunication Centers".

Part 1 of GB/T 47637, titled "Compatible Instruments". The following parts have been published.

---Part 1.2.6kW System;

---Part 2.5.2kW System;

---Part 3: AC/DC appliance input sockets.

This document is equivalent to IEC TS63236-1:2021 "Information and Communication Technology (ICT) Equipment Installed in Data Centers and Telecommunication Center Rooms".

"Standard Equipment Coupler Part 1.2.6kW System". The document type has been changed from an IEC technical specification to a Chinese national standard.