

ICS 31.060.70

CCS K 42



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 6115.1-2026

Replacing GB/T 6115.1-2008

Series capacitors for power systems - Part 1: General

电力系统用串联电容器 第1部分：总则

(English Translation)

Issued on: January 28, 2026

Implemented on: August 1, 2026

Issued by: State Administration for Market Regulation

Table of Contents

Preface

Introduction

1 Scope

2 Normative References

3 Terms and Definitions

4 Usage conditions 6.

4.1 Normal operating conditions

4.2 Ambient air temperature category

4.3 Abnormal Use Conditions

4.4 Abnormal Power System Conditions

5 Quality Requirements and Tests

5.1 Test requirements for capacitor units

5.2 Test Classification

5.3 Capacitance Measurement (Routine Test)

5.4 Measurement of Capacitor Loss Tangent ($\tan\delta$) (Routine Test)

5.5 Terminal Voltage Test (Routine Test)

5.6 AC Voltage Test Between Terminals and Housing (Routine Test)

5.7 Internal Discharge Device Testing (Routine Test)

5.8 Sealing Test (Routine Test)

5.9 Thermal stability test (type test)

5.10 AC voltage test between terminals and housing (type test)

5.11 Lightning impulse voltage test between terminals and enclosure (type test)

5.12 Cold working condition test (type test)

5.13 Discharge Current Test (Type Test)

6 Insulation level

6.1 Insulation withstand voltage

6.2 Creepage distance

6.3 Air gap distance

7 Overload, overvoltage, and load cycle

7.1 Current

7.2 Transient overvoltage

7.3 Load cycle

8 Safety Requirements

8.1 Discharge Devices

8.2 Housing Connection

8.3 Environmental Protection

8.4 Other safety requirements

9 Markings and Instructions

9.1 Unit Marking

9.2 Markings of capacitor banks

9.3 Instruction Manual

10 Guidelines for the selection, installation, and operation of ratings

10.1 Overview

10.2 Reactance of each line, rated reactance of each capacitor bank, and number of stages in each bank (25)

10.3 The rated current of the capacitor bank is 27.

10.4 Overvoltage protection requirements

10.5 Voltage Limitation During Power System Faults

10.6 Protection and switching device

10.7 Selection of Insulation Level

10.8 Correction of Long-Distance Transmission Lines

10.9 Other considerations in application

Appendix A (Normative) Test Requirements and Application Guidelines for External Fuses and Capacitor Units Protected by External Fuses

A.1 General Rule

A.2 Objective

A.3 Terms used in Appendix A

A.4 Performance Requirements

A.5 Experiment

A.6 Guidelines for Coordination of Fuse Protection

A.7 Selection of Fuse

A.8 Information Required by Fuse Users

Appendix B (Informative) Economic Assessment of Losses in Series Capacitor Banks

Appendix C (Informative) Fuse Protection for Capacitor Banks and Arrangement of Units

C.1 Overview

C.2 Internal fuse capacitor bank

C.3 External fuse capacitor bank

C.4 Fuseless capacitor bank

Appendix D (Informative) Typical Wiring Diagrams for Large Series Capacitor Units in Transmission Lines

Appendix E (Informative) Preventive Measures to Avoid Environmental Pollution by Polychlorinated Biphenyls

References

Foreword

This document complies with the provisions of GB/T 1.1-2020 "Standardization Work Guidelines Part 1: Structure and Drafting Rules of Standardization Documents".

Drafting.

This document is Part 1 of GB/T 6115 "Series Capacitors for Power Systems". GB/T 6115 has already published the following parts.

---Part 1: General Provisions;

---Part 2: Protection devices for series capacitor banks;

---Part 3: Internal Fuse;

---Part 4: Thyristor-controlled series capacitors.

This document supersedes GB/T 6115.1-2008 "Series Capacitors for Power Systems - Part 1: General Rules" and is consistent with GB/T 6115.1-Compared to 2008, aside from structural adjustments and editorial changes, the main technical changes are as follows.

a) Changed "(Capacitor) Ambient Air Temperature", "Capacitor", "Capacitor Cell", "Cooling Air Temperature", and "Fuseless Capacitor Bank".

The terms and definitions of "segment (of a series capacitor)," "sub-segment," and "matching current of a nonlinear resistor" (see 3.1, 3.3, 3.4, 3.7) are as follows.

3.28, 3.32, 3.34 (and 3.1, 3.3, 3.4, 3.7, 3.30, 3.34, 3.36 of the 2008 edition);

b) The terms "insulation level" and "power frequency withstand voltage" have been removed (see 3.14 and 3.20 of the 2008 edition);

c) The normal operating conditions have been changed, with the icing thickness changed to "not exceeding 20mm" and the solar radiation changed to "not exceeding 1100W/m²" (see...).

4.1 (4.1 in the 2008 edition);

d) The non-standard usage conditions have been changed to require earthquake acceleration according to the 'moderate or high earthquake level' specified in IEEE Std 693.

The word "degree" has been changed to "horizontal acceleration greater than 0.2g" to better reflect my country's actual situation (see 4.3, 2008 version 4.3);

e) The acceptance criteria for the thermal stability test have been changed (see 5.9, 2008 version 5.9);

f) The test method for the capacitor unit to withstand three positive impulse voltages in the lightning impulse voltage test between the terminals and the casing has been removed.

(See 5.11 in the 2008 edition);

g) An isolation test for the internal fuse has been added (see 5.2.3);

h) Change "Special Test (Durability Test)" to "Aging Test" (see 5.2.4, 5.2.3 in the 2008 version);

i) The standard insulation level for the system nominal voltage of 1000kV has been increased (see Table 3);

j) The content regarding "creepage distance" has been modified (see 6.2, 2008 version 6.2);

k) The contents of Table 4 have been changed (see Table 4, 2008 version);

l) The contents of Tables 5, 6, and 7 have been changed (see 6.3, 2008 version 6.3);

(m) An altitude correction factor has been added to the external insulation performance of devices installed at altitudes above 1000m (see 10.7.2);

n) The requirement for "long-distance transmission line correction" has been added (see 10.8).

This document is modified to adopt IEC 60143-1:2015 "Series capacitors for power systems - Part 1: General".

Compared with IEC 60143-1:2015, this document has undergone the following structural adjustments.

---The positions of the terms "(capacitor's) internal fuse" and "fuseless capacitor bank" have been adjusted;

---The position of the content related to the labeling method for describing insulation levels has been adjusted.

The technical differences between this document and IEC 60143-1:2015 and the reasons therefor are as follows.

a) The scope has been changed in accordance with the requirements of GB/T 1.1, which describes the main contents specified in this document (see Chapter 1).

b) The terms and definitions of "capacitor", "(capacitor's) internal fuse", and "fuseless