

ICS 29.080.10

CCS K 48



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 8287.2-2008

Replacing GB 12744-1991; GB/T 8287.2-1999

**Indoor and outdoor post insulators for systems with nominal
voltage greater than 1000 V -- Part 2: Dimensions and
characteristics**

标称电压高于1000V系统用户内和户外支柱绝缘子 第2部分：尺寸与特性

(English Translation)

Issued on: June 30, 2008

Implemented on: April 1, 2009

Issued by: Standardization Administration of China

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard applies to a nominal voltage greater than 1000V, frequency does not exceed 100Hz AC electrical devices running on the system or equipment used for indoor or outdoor pillar of porcelain or glass insulators and their components, as well as indoor post insulators of organic material. This section can also be used as a DC system Insulator provisional standards. This section includes the insulator is mainly used for isolating switches, breakers, and fuses and other electrical equipment.

Document data

International classification (ICS): 29.080.10.

Chinese classification (CCS): K48.

Estimated length of the Chinese original: 39,344 words.

Adopted international standard: IEC 60273-1990, MOD.

Supersedes the earlier edition GB 12744-1991; GB/T 8287.2-1999.