

ICS 27.140
CCS K 55



**NATIONAL STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

GB/T 9652-1988

**Specification of hydraulic turbine governing systems
(English Translation)**

Issued on: June 4, 2019

Implemented on: January 1, 2020

**Issued by: State Administration for Market Regulation, China National
Standardization Administration**

Table of Contents

- Foreword
- 1 Scope
- 2 Normative references
- 3 Working conditions

Foreword

GB/T 9652 is divided into the following two parts.

---GB/T 9652.1 "Technical conditions for turbine governing system";

---GB/T 9652.2 "Turbo Turbine Speed Control System Test".

This part is the first part of GB/T 9652.

This part is drafted in accordance with the rules given in GB/T 1.1-2009.

This part replaces GB/T 9652.1-2007 "Technical Conditions for Hydraulic Turbine Control System", compared with GB/T 9652.1-2007 the changes are as follows.

--- The scope of application has been modified (see Chapter 1);

--- Modified the working conditions (see 3.3, 3.4, 2007 version 3.3);

--- Considering that the mechanical hydraulic governor and analog circuit governor have been discontinued in China for more than ten years, the current turbine governor products are it is a microcomputer type governor, so the relevant provisions of the mechanical hydraulic governor and the analog circuit electro-hydraulic governor have been deleted (see Table 2, 2007).

Versions 4.4.3.3, 4.6.1, Table 2);

--- Modified the speed dead zone assessment requirements (see 4.1.3);

--- Increased the technical requirements of the pump turbine governor system (see 4.3.12);

--- Adjusted and supplemented the manual and automatic no-load frequency swing assessment indicators (see 4.2.1, 4.2.2, 4.2.3);

--- In view of the actual status of the stationary time of the relay of the large-scale unit turbine governing system, the indicator of the stationary time evaluation of the relay Adjustments have been made (see 4.2.4);

--- Adjusted and supplemented the 100% load assessment requirements (see 4.2.5);

- Added technical requirements for frequency modulation and power regulation (see 4.2.6, 4.2.7);
- Increased the technical requirements for the regulation of isolated networks (see 4.2.8);
- Modified the volume requirement for available oil for pressure tanks/accumulators (see 4.4.2);
- Modified the standby pump starting conditions (see 4.4.5, 4.4.10);
- Increased the division of pressure levels (see 4.4.12);
- Increased the indicator requirements for the start interval of the oil pump motor (see 4.4.14);
- Removed the terms of the through-flow governor (see 4.6.7 of the 2007 edition);
- Increased the technical requirements of the impact turbine governing system and the turbine governing system with pressure regulating valve control (see 4.3.10, 4.3.11);
- Increase the technical requirements of the two-way tubular tidal unit speed control system (see 4.3.13);
- Increased the indicator requirements for the positional drift of the servomotor under manual conditions (see 4.3.19);
- Increased the requirements for the oil pressure drift of the speed control system (see 4.3.20);
- Adjusted and supplemented the technical requirements of the governor and hydraulic unit/component modules (see 4.5).

This section uses the redrafting method in accordance with IEC 61362:2012 "Guidelines for the specification of turbine control systems", with IEC 61362:2012 the degree of consistency is non-equivalent.

This part was proposed by China Electrical Equipment Industry Association.

This part is under the jurisdiction of the National Turbine Standardization Technical Committee (SAC/TC175).

This section is mainly drafted by. Tianjin Electric Science Research Institute Co., Ltd., China Institute of Water Resources and Hydropower Research Institute of Automation, three Xia Hydropower Plant, Dongfang Motor Control Equipment Co., Ltd., China Hydropower Consulting Group East China Survey and Design Institute, Guodian Nanrui Technology Co., Ltd.

Co., Ltd., Changjiang Survey and Design Research and Research Co., Ltd., Wuhan Guoshang Sanlian Hydropower Equipment Co., Ltd., China Datang Group Institute of Hydropower Research, Wuhan University, Xi'an University of Technology.

1 Scope

This part of GB/T 9652 specifies the working conditions, technical requirements, scope of supply and spare parts, drawings and drawings of the turbine governing system.

Information, nameplate, packaging, transportation and storage, warranty period, etc.

This section applies to the design, manufacture and acceptance of the turbine governing system (including the pump turbine governing system).

2 Normative references

The following documents are indispensable for the application of this document. For dated references, only dated versions apply to this article.

Pieces. For undated references, the latest edition (including all amendments) applies to this document.

GB/T 150.1 Pressure vessels - Part 1. General requirements GB/T 150.2 Pressure Vessels Part 2. Materials GB/T 150.3 Pressure Vessels Part 3. Design GB/T 150.4 Pressure vessels - Part 4. Manufacture, inspection and acceptance GB/T 191 packaging storage and transportation icon GB/T 3047.1 Basic size series of panels, shelves and cabinets with a height of 20mm GB/T 3797 electrical control equipment GB/T 4588.1 Non-metallized hole single-sided printing board sub-specification GB/T 4588.2 Metallized hole single-sided printing plate sub-specification GB/T 8564 Hydrogenerator Set Installation Technical Specifications GB/T 10886 three screw pump GB 11120-2011 Turbine oil GB/T 11805 Hydrogenerator set automation components (devices) and their systems basic technical conditions GB/T 14039-2002 Hydraulic transmission oil solid particle pollution level code GB/T 17626.4 Electromagnetic compatibility test and measurement technology Electrical fast transient burst immunity test GB/T 20663 energy storage pressure vessel GB/T 25133 hydraulic system assembly pipeline flushing method Technical guidelines for grid-connected operation of DL/T 1245 turbine regulating system JB/T 4711 Pressure Vessel Coating and Transport Packaging JB/T 7036 hydraulic isolation accumulator technical conditions JB/T 7041 hydraulic gear pump JB/T 8091 screw pump test method

3 Working conditions

3.1

The maximum stroke of the servomotor is compatible with the full opening of the guide vane. For medium, small and extra small speed controllers, the actual maximum opening of the vanes corresponds to at least More than 80% of the maximum stroke of the servo. The working capacity selection of the governor and the hydraulic device is suitable.

3.2

Pipe installation, welding, cleaning and inspection shall comply with the provisions of GB/T 8564 and GB/T 25133.