

ICS 07.060
CCS A 45

HY

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

HY/T 232-2018

**Specification for acceptance test of seawater cooling tower
(English Translation)**

Issued on: February 13, 2018

Implemented on: May 1, 2018

**Issued by: Ministry of Natural Resources of the People's Republic of
China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the test procedures for the thermal performance, noise and drift rate of seawater cooling towers, as well as methods for parameter measurement, data processing and results evaluation. This standard is applicable to the acceptance test of newly built or rebuilt wet mechanical ventilation and natural ventilation seawater cooling towers. The non-acceptance seawater cooling tower test can refer to this standard. This standard does not apply to the testing of seawater cooling towers in which the "smoke tower is integrated".

Document data

International classification (ICS): 07.060.

Chinese classification (CCS): A45.

Estimated length of the Chinese original: 26,267 words.

Standards quoted by this document

GB/T 3785; GB/T 7190; GB 12348; GB 17378.4; GB/T 23248-2009