

JB

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

JB/T 8625-2008

Replacing JB/T 8625-1997

**Electrostatic precipitators - Level controllers - Technical
requirements**

电除尘器 料位控制器 技术要求

(English Translation)

Issued on: March 12, 2008

Implemented on: September 1, 2008

**Issued by: Ministry of Industry and Information Technology of the
People's Republic of China**

Table of Contents

Foreword
1 Scope
2 Normative References
3 Structural Types, Connecting Modes, Basic Parameters and Models
3.1 Structural Types
3.2 Connecting Modes
3.3 Basic Parameters
3.4 Product Models
4 Technical Requirements
4.1 Operation
4.2 Action Delay Time
4.4 Medium Temperature
4.5 Seal and Dust Proof
4.6 Insulation Property
4.7 Vibration Resistance Property
4.8 Packing and Transport Properties
4.9 Appearance
5 Test Methods
5.1 Operation Test
5.2 Action Time Delay Test
5.3 Electrifying Property Test of the Contact Point
5.4 Medium Temperature Test
5.5 Seal and Dustproof Inspection
5.6 Insulating Property Test
5.7 Vibration Resistance Property Test
5.8 Property Test of Packing and Transport
5.9 Appearance Inspection
6 Inspection Rules
6.1 Delivery Inspection
6.2 Type Inspection
7 Mark, Packing and Storage
7.1 Mark

7.2 Packing

7.3 Storage

1 Scope

This standard specifies the structural type, connecting mode, basic parameters, model, technical requirements, test methods, inspection rules, mark, packing and storage of the contact-type level controller and the radio frequency level controller for the electrostatic precipitator.

This standard is applicable to the contact-type level controller and radio frequency admittance level controller for quantitative discharging of the ash hopper of the self-controlled electrostatic precipitator.

This standard is also applicable to other mechanical level control switches, rotary level controller and capacitive material-level controller.

2 Normative References

The following documents contain provisions which, through reference in this standard, constitute provisions of this standard. For dated reference, subsequent amendments to (excluding any amendments), or revisions of, any of these publications do not apply. However, the parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent editions of the standards. For undated references, the latest edition of the normative document referred to applies.