

ICS 75.180.10
CCS E 94

SY

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

SY/T 10034-2020

Replacing SY/T 10034-2000

**Recommended practice for fire prevention and control on fixed
open-type offshore production platforms**

敞开式海上生产平台防火与消防的推荐作法

(English Translation)

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies recommended practices for the design, inspection, and maintenance of fire protection systems and minimize the possibility of accidental fire. It emphasizes the need for fire-fighting training for personnel, regular drills, and the development of safe escape methods and procedures. The fire protection system discussed in this standard is intended to respond early to the initial fire to prevent its spread. However, this discussion does not intend to preclude the use of a wider range of practices to adapt to special circumstances, or even replace it with other equivalent or higher-level protection systems. This standard applies to fixed and open offshore production platforms installed under non-extreme climatic conditions. Such platforms have sufficient natural ventilation to minimize gas phase accumulation. For enclosed areas, such as living areas and enclosed equipment areas usually installed on such platforms are also discussed. Installed under extreme conditions or due to other reasons

Document data

International classification (ICS): 75.180.10.

Chinese classification (CCS): E94.

Estimated length of the Chinese original: 50,569 words.

Supersedes the earlier edition SY/T 10034-2000.

Standards quoted by this document

ASTM D 2996; ASTM E 119; ASTM E 152; ASTM E 163; ASTM E 814; API PUBL 2030; API PUBL 2218; API RP 14C; API RP 14E; API RP 14F; API RP 14FZ; API RP 14J; API RP 75; API RP 500; API RP 505; API RP 520; API RP 521; API RP 2003; API RP T-1