

ICS 33.100
CCS L 06

YD

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

YD/T 2191.7-2010

**Electromagnetic compatibility in telecommunication: Installation and
mitigation guidelines. Part 7: Degrees of protection provided by
enclosures against electromagnetic disturbances**

电信设备安装的电磁兼容及缓和措施 第7部分：电磁干扰保护壳体的等级
(English Translation)

Issued on: December 29, 2010

Implemented on: January 1, 2011

Issued by: Ministry of Industry and Information Technology

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the 10kHz ~ 40GHz band shell body protection against electromagnetic interference performance requirements, methods of testing and grading defined process. In-room electronic and (or) electrical equipment prior to installation, you need to measure the performance shielded housing, thereby providing a repeatable Review estimates empty mechanical housing (including racks and cabinets) electromagnetic shielding performance of the method, and determine its Shielding level. Classification used in this section (level) systematic approach to describe the case of electromagnetic interference protection, including the empty shell on the closed area to pass each other in their internal and external protection of electromagnetic energy.

Document data

International classification (ICS): 33.100.

Chinese classification (CCS): L06.

Estimated length of the Chinese original: 20,296 words.

Adopted international standard: IEC/TR 61000-5-7, MOD.

Standards quoted by this document

IEC/TR 61000-5-7