

ICS 29.200
CCS M 41

YD

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

YD/T 2657-2021

Replacing YD/T 2657-2013

**High-temperature valve-regulated lead-acid battery for
communication**

通信用高温型阀控式铅酸蓄电池

(English Translation)

Issued on: December 2, 2021

Implemented on: April 1, 2022

Issued by: Ministry of Industry and Information Technology

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard specifies the terms, symbols, technical requirements, test methods, inspection rules, marking, packaging, transportation and storage of high-temperature VRLA batteries for telecommunication. This standard applies to high-temperature VRLA batteries used in indoor communication base stations, outdoor communication base stations, core computer rooms and data centers. High-temperature VRLA batteries used in other systems such as solar energy and wind energy can also be referred to. use.

Document data

International classification (ICS): 29.200.

Chinese classification (CCS): M41.

Estimated length of the Chinese original: 25,295 words.

Supersedes the earlier edition YD/T 2657-2013.