

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

YD/T 2768.3-2018

**Thermal control equipment for outdoor telecommunication
enclosure -- Part 3: Integrated heat pipe air conditioner for
Outdoor telecommunication Shelter**

通信户外机房用温控设备 第3部分：机柜用空调热管一体化设备

(English Translation)

Issued on: December 21, 2018

Implemented on: April 1, 2019

Issued by: Ministry of Industry and Information Technology

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard specifies the terms and definitions, product classification, technical requirements, test methods, inspection rules, and marking, packaging, transportation and storage of integrated air conditioning heat pipe integrated temperature control equipment for communication outdoor cabinets. This standard is applicable to air-conditioning heat pipe integrated temperature control equipment embedded in a communication outdoor cabinet with an internal heat generation of not more than 6000W.

Document data

Chinese classification (CCS): P48.

Estimated length of the Chinese original: 20,217 words.