

ICS 27.200
CCS P 48

YD

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

YD/T 3223-2017

Integrated heat pipe air conditioner for telecom stations/sites

通信局站用热管空调一体机

(English Translation)

Issued on: April 12, 2017

Implemented on: July 1, 2017

Issued by: Ministry of Industry and Information Technology

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the product type classification, technical requirements, test methods, inspection rules, markings, packaging, transportation and storage of heat pipe air conditioners (hereinafter referred to as all-in-one machines) used by stations in the Communications Bureau. This standard applies to all-in-one units with air-cooled air conditioning systems with a nominal cooling capacity of not more than 14 kW, and is not applicable to the embedded one-piece machine for cabinets.

Document data

International classification (ICS): 27.200.

Chinese classification (CCS): P48.

Estimated length of the Chinese original: 15,146 words.

Standards quoted by this document

GB/T 191; GB/T 2829-2002; GB/T 3873; GB 4706.1-2005; GB/T 7725-2004; GB/T 14295-2008; GB/T 17758-2010; YD/T 1363.3